

1 NEW YORK STATE
2 DEPARTMENT OF ENVIRONMENTAL CONSERVATION

3
4 In the Matter of a Renewal and Modification of a State
5 Pollutant Discharge Elimination System (“SPDES”) Permit
6 Pursuant to article 17 of the Environmental Conservation Law
7 and Title 6 of the Official Compilation of Codes, Rules and
8 Regulations of the State of New York parts 704 and 750 *et seq.*
9 by Entergy Nuclear Indian Point 2, LLC and Entergy Nuclear
10 Indian Point 3, LLC, Permittee,

DEC # 3-5522-00011/00004
SPDES # NY-0004472

11
12 -and-

13
14 In the Matter of the Application by Entergy Nuclear Indian
15 Point 2, LLC and Entergy Nuclear Indian Point 3, LLC,
16 and Entergy Nuclear Operations, LLC for a Certificate
17 Pursuant to §401 of the Federal Clean Water Act.

DEC # 3-5522-00011/00030
DEC # 3-5522-00011/00031

18
19
20 **PRE-FILED SUR-REBUTTAL TESTIMONY OF ROBERT FAGAN RELATING TO**
21 **THE AFRICAN AMERICAN ENVIRONMENTALIST ASSOCIATION’S EXHIBIT 18**
22 **ON BEHALF OF INTERVENORS RIVERKEEPER, INC., SCENIC HUDSON, INC.,**
23 **AND NATURAL RESOURCES DEFENSE COUNCIL, INC.**
24

25 **Q. Please state your name, business address and occupation.**

26 A. My name is Robert M. Fagan. I am a Principal Associate at Synapse Energy Economics,
27 485 Massachusetts Ave., Cambridge, MA 02139.

28
29 **Q. Have you previously provided testimony with respect to the above-**
30 **captioned proceeding and appeal?**

31
32 A. Yes. I have provided prefiled direct testimony, dated February 28, 2014, prefiled rebuttal
33 testimony, dated March 28, 2014, as well as live testimony on the record before this Tribunal on
34 April 11, 2014 in the above-captioned State Pollutant Discharge Elimination System (“SPDES”)
35 proceeding with respect to the potential impacts to electric power sector reliability, electric
36 power sector air emissions, and electric power sector price impacts associated with the
37 construction and operation of the closed-cycle cooling system configurations proposed by the
38 New York State Department of Environmental Conservation (NYSDEC) and Entergy for the
39 Indian Point nuclear power plant (“IPEC”), in order to inform the analysis being conducted in

1 connection with the above-captioned permit proceeding by NYSDEC under New York’s State
2 Environmental Quality Review Act (SEQRA). My educational and professional background and
3 qualifications are described in my previous testimony and my full curriculum vitae, is presently
4 in evidence as **Riverkeeper Exhibit 108**.

5
6 **Q. Why is Riverkeeper offering your sur-rebuttal testimony?**

7 A. I understand that the Tribunal has authorized Riverkeeper to offer prefiled sur-rebuttal
8 testimony in response to an exhibit that was offered by the African-American Environmentalist
9 Association (“AAEA”) during the April 2014 adjudicatory hearings, AAEA Exhibit 18.
10 Although AAEA Exhibit 18 was not offered or referred to in AAEA’s prefiled testimony or
11 report,¹ this exhibit presented AAEA’s analysis with respect to specific power replacement
12 resources and purported air emissions impacts associated with the closure of IPEC. I did not
13 have the benefit of responding to this analysis in any capacity as of the time it was offered to the
14 tribunal. Thus, my testimony herein responds to AAEA Exhibit 18 (which AAEA has broken up
15 and sub-designated as AAEA Exhibits 18A through 18E), as well as the live testimony provided
16 by AAEA’s witnesses on April 17, 2014 during which AAEA Exhibit 18 was discussed and
17 explained, and the documents identified as “reliance documents” which AAEA provided in
18 connection with AAEA Exhibit 18 subsequent to offering AAEA Exhibit 18 at the hearing.²

19
20 **Q. What have you reviewed and relied upon in preparation of this sur-**
21 **rebuttal testimony?**

22
23 A. In addition to materials I have previously identified as having reviewed and relied upon,³

¹ AAEA Exhibit 1, *Fish Eggs Versus Asthmatic Children In Harlem*, AAEA (February 2014); Rebuttal Testimonies of Norris McDonald, John McCormick, Derry Bigby, and Dan Durett Regarding Fish Eggs Versus Asthmatic Children in Harlem: Environmental Justice Issues Related to Closing Indian Point Energy Center, On Behalf of Intervenor African American Environmentalist Association (March 25, 2014).

² Excerpt Spreadsheet, file name: 2012 EIA Form 860 Indian Point 2 and 3, submitted by AAEA on April 22, 2014, now offered as **Riverkeeper Exhibit 181**, Excerpt Spreadsheet, file name: 2013 EIA Form 923 Indian Point, submitted by AAEA on April 22, 2014, now offered as **Riverkeeper Exhibit 182**, Excerpt Spreadsheet, file name: Form 923 6 Plants, submitted by AAEA on April 22, 2014, now offered as **Riverkeeper Exhibit 183**.

³ See Direct Testimony of Robert M. Fagan Regarding Air Emissions and Electric System Reliability Impacts of Closed-Cycle Cooling, on Behalf of Intervenor Riverkeeper, Inc., Scenic Hudson, Inc., and Natural Resources Defense Council, Inc (February 28, 2014) at 15-17; Rebuttal Testimony of Robert M. Fagan Regarding Replacement Power Air Emissions and Electric System Reliability Impacts of Closed-Cycle Cooling, on Behalf of Intervenor Riverkeeper, Inc., Scenic Hudson, Inc., and Natural Resources Defense Council, Inc (March 28, 2014) at 40.

1 I have reviewed AAEA Exhibit 18, associated “reliance documents” identified and provided by
2 AAEA, and the transcript of AAEA’s witnesses’ testimony from April 17, 2014 during the
3 adjudicatory hearings on the issue of closed-cycle cooling.
4

5 **Q. Are there any limitations to your sur-rebuttal testimony that you need**
6 **to identify at the outset?**

7
8 A. I understand that Riverkeeper has not yet cross-examined any of AAEA’s witnesses and
9 that the July 11, 2014 filing date for this testimony will pre-date Riverkeeper’s cross examination
10 of AAEA’s witnesses. I obviously cannot respond to any subsequent testimony from AAEA’s
11 witnesses in connection with AAEA Exhibit 18 via the testimony herein.
12

13 **Q. What are AAEA Exhibits 18A-E?**

14 A. According to AAEA witness Norris McDonald, AAEA Exhibits 18A-E present an
15 “analysis of the particular power plants that could possibly have to replace power from Indian
16 Point during a construction outage.”⁴ This analysis purportedly estimates what replacement
17 power needs would be in New York City in the year 2013 if IPEC is unavailable, and assumes
18 that IPEC provides thirty percent (30%) of its power to New York City. AAEA’s analysis
19 concludes that the absence of IPEC power generation would result in certain increases in NOx
20 and CO₂, to support AAEA’s claim that the closure of Indian Point will result in disproportionate
21 negative impacts on air quality in environmental justice communities.
22

23 AAEA’s Exhibit 18A lists the capacity, operating status, in-service year, fuel source, operating
24 months and county location of a subset—that is, just 21 units from six plants—of the generation
25 available to operate in the New York City load zone, also known as zone J of the New York

⁴ CCC (McDonald Cross) atTr. at 9951:2-9. Despite this testimony, it is clear that in this proceeding AAEA has only offered testimony and evidence with respect to air quality impacts and replacement power issues associated with Entergy deciding not to implement closed-cycle cooling at IPEC and instead deciding to shut down the plant permanently. As I have previously indicated, I understand that Riverkeeper’s position is that the shutdown of Indian Point is not properly relevant to a SEQRA review in connection with NYSDEC’s April 2, 2010 Denial of Entergy’s requested Clean Water Act Section 401 water quality certification., and any response to AAEA’s analysis herein is without prejudice to Riverkeeper’s position.

1 Independent System Operator’s (NY ISO) dispatching construct. The total of summer capacity
2 listed in Exhibit 18A is 4,487 MW.

3
4 AAEA Exhibit 18C consists of additional information for the six power plants listed in AAEA
5 Exhibit 18A. In particular, AAEA Exhibit 18C contains the power plant capacity information for
6 those six power plants plus an estimate of the net generation (in MWh) during the 2013 ozone
7 season (by which AAEA presumes May 1 through September 30) for these same plants, their
8 NO_x emission rate, and the total ozone season NO_x emissions. The energy and NO_x data are
9 from the U.S. Energy Information Administration (EIA) form 923 reporting for 2013.

10
11 AAEA Exhibit 18D is AAEA’s “Estimate of Additional NO_x During May through September to
12 Replace the 30% of IPEC Power” while AAEA Exhibit 18E is AAEA’s “Estimate of Additional
13 CO₂ During May through September to Replace the 30% of IPEC Power.” I interpret these to be
14 AAEA’s estimates of what replacement power needs would be in New York City if IPEC were
15 out of service during the ozone season in 2013, and air emissions increases resulting therefrom.

16
17 **Q. Has AAEA provided a technically-supportable estimate of the effects of a**
18 **potential IPEC outage on either replacement power needs, or air emissions**
19 **from power plants in New York City?**

20
21 A. No, they have not. For a number of reasons, as I will describe in further detail below,
22 AAEA’s analysis as contained in the multiple parts to their Exhibit 18 is deficient on a number
23 of fundamental levels. Consequently, there is no basis for, and I disagree with, AAEA’s core
24 assertions, indicated in Exhibit 18D:

- 25 1) that the six New York City power plants identified by AAEA would be expected to
26 provide all the replacement power that may need to be sourced from New York zone J
27 generation if IPEC was not available during May – September under a future IPEC
28 outage scenario;
- 29 2) that replacement power needs (in terms of MWH requirements during May – September
30 in New York zone J) would be as AAEA indicates in Exhibit 18D;⁵

⁵ A close review of Exhibit 18D reveals that AAEA assumes an increased energy generation need in New York City during May-September of 2,583,480 MWh, or 2,583.48 GWh, equal to AAEA’s column “I” total (9,357,743 MWh) minus column “C” (6,774,264 MWh).

- 1 3) that the AAEA-identified six power plants collectively would, thus, produce 1,353 tons
2 of NO_x emissions during May – September; and
3 4) that the parts of New York City that contain those six AAEA-identified power plants
4 would see an ozone season increase in NO_x emissions of 599 tons in the event that IPEC
5 was out of service during May – September.

6 While AAEA’s conclusions with regard to CO₂ emissions increases are similarly unreliable, my
7 testimony here does not specifically address AAEA’s claims with respect to CO₂ emissions.
8 This is because my direct and rebuttal testimony has already addressed the overall effect of
9 cooling tower construction outages on CO₂ emissions in New York State over time, under
10 different resource scenarios, and because NO_x emissions are a pollutant of issue for local air
11 quality impacts, whereas CO₂ emissions are not.

12

13 **Q. Is estimating what the replacement power needs may be in New York**
14 **City in 2013 a viable means of informing the question of replacement power**
15 **needs in the event of an IPEC outage in a future year for cooling tower**
16 **construction?**

17 A. No, not without accounting for major electric system changes expected across the system
18 over a number of years extending out at least to the latter part of this decade, since major
19 infrastructure improvements are planned over that period and an outage at IPEC for the
20 construction of cooling towers is not expected to occur until later years, around 2020.⁶ Prior to
21 year 2020 – and as early as 2016 – a number of changes to the electric power system are
22 currently required to, or will otherwise likely, be in place. Primarily, additional transmission
23 system support and additional regional generation resources will be installed. Also, additional
24 demand side measures and additional solar photovoltaic (PV) energy resources in the New York
25 City, Lower Hudson Valley, and Long Island zones will be in place. All of these changes can
26 impact, and would require careful consideration in connection with, the assessment of
27 replacement power needs in the event of an IPEC outage. By narrowly and erroneously focusing
28

⁶ See CCC (Clubb Cross) at Tr. 12116:30 to 12118:17 (citing Appendix 6B to Entergy Exhibit 7) (in relation to Entergy’s proposed Enercon cooling towers, indicating that it would take four years from the initiation of construction before a construction-related outage would occur); Tetra Tech, Inc., IPEC ClearSky™ Retrofit: Planning Schedule (March 27, 2014), **DEC Staff Exhibit 278** (in relation to DEC Staff’s cooling tower configuration, indicating outage construction commencing in March 2024).

1 on the year 2013, AAEA does not account for any of these planned major electric system
2 changes.

3

4 **Q. What is your understanding of AAEA’s assumption about the amount of**
5 **power that would need to be replaced in New York City zone J in the event of a**
6 **construction outage at IPEC?**

7

8 A. AAEA Exhibits 18D and E state that “IPEC Units 2&3 deliver 30% Net Gen to Zone J,”
9 and AAEA witness, Mr. McCormick testified that he assumed that 30% of IPEC’s power was
10 going into Zone J.⁷ Thus, AAEA assumed that replacement power in 2013 in zone J would have
11 been required for 30% of the output of the IPEC units.

12

13 **Q. Do you agree with this assumption?**

14

15 A. No, this assumption is unsupported. If IPEC is not in service during the ozone season,
16 for any reason, incremental “replacement” energy amounts from New York City zone J units
17 would be much lower. While the exact amount of ozone season replacement power from zone J
18 sources would depend on the year in which one is assessing an IPEC outage and on the resource
19 mix and net load requirements at the time, AAEA has overestimated the amount of power that
20 would need to be replaced in zone J. My previous analysis of air emissions impacts provides a
21 more accurate estimation of power replacement needs, on an annual basis, in the event of an
22 IPEC outage. In addition, for this sur-rebuttal testimony, I extracted the monthly data for
23 generation from zone J from my original analysis, (as is summarized in Table 3 below of this
24 sur-rebuttal), which reinforces my original findings.

25

26 **Q. In your previous analysis of air emissions impacts from construction**
27 **outages at IPEC, how did you estimate replacement power needs?**

28

29 A. Unlike Mr. McCormick’s arbitrary assumptions about replacement power needs, I used
30 industry-standard economic dispatch models that respected the major transmission constraints in
31 New York State and accounted for the economics of electric power dispatch, essentially

⁷ Estimate of Additional NO_x During May Through September to Replace the 30% of IPEC Power, **AAEA Exhibit 18D**; Estimate of Additional CO₂ During May Through September to Replace the 30% of IPEC Power, **AAEA Exhibit 18E**; CCC (McCormick Cross) at Tr. at 9990:8-11.

1 mirroring the manner in which the power system is actually dispatched. I accounted for
2 anticipated changes in the electric power system in New York State, and conducted scenario
3 assessment to test the effects under a range of future conditions representing different resource
4 mixes.

5
6 **Q. What did your previous analysis show with regard to replacement
7 power needs in the event of an outage at IPEC?**

8
9 A. In the Synapse report accompanying my direct testimony, Tables 1 and 2 listed the
10 proportion of IPEC energy replaced with New York City zone J resources. Depending on the
11 year and scenario considered, I computed replacement power needs in New York City that
12 ranged from negative – meaning less generation from New York City units when IPEC was out
13 of service – to as much as 26% of IPEC output for only the most conservative scenario in the
14 year 2025. In the “base” scenario, comparing IPEC out of service in 2016 and making no
15 changes to the level of energy efficiency or renewable resource deployment in the state, I
16 estimated a replacement power need of 18% of IPEC required from zone J resources. The
17 remaining need in that scenario comes from imports, and gas and coal resources from other New
18 York State zones, including the Lower Hudson Valley, the Capital region, and northern and
19 western New York State. In scenarios with higher levels of energy efficiency and renewable
20 resources, less than 10% of replacement power needs come from New York City resources.

21

22 **Q. What did extracting data from the May-September months show with
23 regard to replacement power needs in the event of an outage at IPEC?**

24

25 A. For two key scenarios, over the period of 2016-2019, our modelling data for the ozone
26 season showed incremental zone J replacement energy (i.e., replacement power required from
27 zone J units) that ranged from 5.1% to 10.8% of IPEC May-September energy in scenarios
28 where IPEC was not in service in those months (as reflected in Table 3 below). Once again, such
29 an estimate follows from a detailed economic redispatch of the system, as conducted with our
30 PROSYM modeling. Notably, AAEA did not conduct any form of economic redispatch in
31 arriving at its findings related to replacement power needs.

32

1 **Q. Does AAEA’s Exhibit 18 consider all of the generation capacity that is**
2 **available to operate in New York City (NY ISO zone J) to be a source of**
3 **replacement power for IPEC, if necessary?**
4

5 A. No. AAEA Exhibit 18 only lists and considers 21 generating units from 6 power plants
6 located in New York City zone J and does not consider all of the generation that is available to
7 New York City. In reality, there are roughly 130 individual units from 26 power plants available
8 to operate in New York City zone J.

9
10 Table 1 below lists the total generation capacity that was available to the New York City zone J,
11 the summer MW rating of those units, and the actual 2013 annual energy produced by the units.
12 It also includes the average annual capacity factor for the units, a measure of “headroom” for
13 more energy production, on an annual basis. Some units have been aggregated into reasonable
14 groupings of capacity – for example, there are 16 separate combustion turbine units at the
15 Narrows location – those are grouped as a total of 283 MW.

16

1 **Table 1. 2013 Summer Capacity,⁸ Annual Energy, and Average Capacity Factor, by Plant Group, New York**
 2 **City Zone J Electric Power Resources**
 3

| Units | Summer MW | GWh 2013 | Annual Ave. Capacity Factor based on Summer MW |
|--|--------------|---------------|---|
| East River CC 1&2 | 288 | 2,465 | 97.9% |
| NYPA Astoria CC1&2 (2006) | 464 | 3,370 | 82.9% |
| Brooklyn Navy Yard | 261 | 1,857 | 81.1% |
| Ravenwood CC 2004 | 218 | 1,471 | 77.0% |
| Astoria II CC3 and 4 | 544 | 3,084 | 64.8% |
| JFK cogen | 118 | 637 | 61.4% |
| Astoria East Energy cc1 and cc2 | 555 | 2,796 | 57.5% |
| Linden Cogen (NJ) | 754 | 3,083 | 46.7% |
| East River steam 6&7 Cogen | 322 | 743 | 26.4% |
| NYPA Gowanus/Kent/Pouch GTs | 171 | 343 | 22.9% |
| Arthur Kill 2 steam | 338 | 670 | 22.6% |
| Bayonne Energy Center (NJ) | 471 | 829 | 20.1% |
| Ravenwood steam 2 | 364 | 620 | 19.4% |
| Astoria 3/5 steam | 754 | 1,065 | 16.1% |
| Arthur Kill 3 steam | 500 | 685 | 15.7% |
| Ravenwood steam 1 | 366 | 427 | 13.3% |
| NYPA Vernon Blvd GTs | 80 | 80 | 11.4% |
| Ravenwood steam 3 | 964 | 593 | 7.0% |
| NYPA Harlem Rv and Hellgate GTs | 160 | 86 | 6.1% |
| Narrows GTs | 283 | 123 | 5.0% |
| Astoria GTs circa 1970 | 506 | 58 | 1.3% |
| Astoria GT 01 | 15 | 1 | 1.1% |
| Gowanus GTs | 551 | 54 | 1.1% |
| Ravenwood GT/Jet | 322 | 27 | 1.0% |
| Arthur Kill GT 1 | 12 | 1 | 0.8% |
| ConEd 59th, 74th, and Hudson Ave GTs | 78 | 2 | 0.2% |
| Grand Total NYC Zone J Generation, 2013 | 9,458 | 25,169 | 30.4% |
| | | | |
| Excluding AAEA Exhibit 18A Units | 4,487 | | |
| | | | |
| Remaining Capacity Not in AAEA Exhibit 18A | 4,971 | | |

4
 5 Source: NY ISO 2014 Gold Book, Table III data, summarized by Synapse. Capacity factor computed by Synapse.
 6

7 Table 1 shows that there was roughly 9,458 MW available for operation in New York City in
 8 2013. This 9,458 MW is 4,971 MW more than AAEA’s estimate, which only assumes just 4,487
 9 MW would be available to “replace” IPEC power in 2013. In 2013, New York City zone J units
 10 produced 25,169 GWh, or 25.169 million MWh.

⁸ Power plants have “nameplate” ratings, and summer and winter ratings. Summer ratings can be limited by temperature concerns at power plants. Nameplate ratings are usually slightly higher than summer ratings.

1 **Q. What is the significance of AAEA’s exclusion of more than 4,900 MW of**
2 **available summer capacity from its analysis?**

3
4 A. This exclusion contributes significantly to the inaccuracies of the replacement power
5 assessment conducted by AAEA. In particular, all 9,458 MW of zone J capacity would be
6 available to operate in New York City during the summer months. AAEA has incorrectly
7 restricted the set of units available to those with “Sufficient Summer Name Plate Capacity to
8 Accommodate Replacement of the Lost IPEC MWH.” AAEA’s designation of plants with
9 “sufficient summer name plate capacity” is misleading since all power plant zone J capacity has
10 the potential to “accommodate” replacing IPEC power in the event of an outage. Mr.
11 McCormick testified that he limited his power plant selection to those plants that provide
12 baseload power and can “make up for the IPEC loss” and that he “eliminated” plants that
13 provided smaller amounts of power.⁹ However, economic dispatch of a system without IPEC
14 would not exclude the ability of such units to provide replacement power, if, as, or when needed.
15 There is no requirement to “match” the baseload character of IPEC’s energy output with only
16 baseloaded plants when considering “replacement” energy needs.

17
18 **Q. So then, if replacement power is needed in the event of a closed-cycle**
19 **cooling construction-related outage at IPEC, would that power necessarily**
20 **come only from the six power plants AAEA has considered in its analysis?**

21
22 A. No. It could come from *any* of the 9,458 MW of available zone J capacity.

23
24 **Q. If replacement power is required from zone J resources, how would it be**
25 **determined where that energy would come from?**

26
27 A. The exact source(s) of replacement power would be determined according to both
28 economics of dispatch and any New York City transmission congestion that may exist.
29 Generally, economic dispatch determines the order in which any required “replacement” power
30 would be sourced, and the presence (or absence) of transmission congestion could also affect the
31 choice of replacement power. An economic dispatch of the resources in the New York State
32 market would determine the makeup of energy across all resources in the event of an IPEC
33 outage. That dispatch would reflect the presence of transmission constraints into and within

⁹ CCC (McCormick Cross) at Tr. at 9980:21-9981:18; 9985:11-9986:2.

1 New York City, as well as relevant changes to and other realities of the New York State
2 electricity grid and power system.

3

4 **Q. How did AAEA Witness, Mr. McCormick, determine replacement power**
5 **sources in the event of an IPEC outage?**

6

7 A. Mr. McCormick did not conduct an economic dispatch model respectful of market
8 economics and transmission constraints for a scenario involving an outage at IPEC. Instead,
9 AAEA made unsupported assumptions about the level of replacement power needs required from
10 New York City units, as discussed above, and then assumed that the replacement energy would
11 come from a subset of the resources available to the NY ISO for dispatch in New York City. In
12 particular, Mr. McCormick used an *ad hoc* mechanism that selectively identified six of the larger
13 units in New York City to provide that level of replacement power. Mr. McCormick estimated
14 what “headroom” (meaning what capability to turn up output) existed on those six plants during
15 the summer of 2013, and then assumed that all the power was to be made up by the headroom
16 remaining on those units.

17

18 Table 2 below lists all Zone J generation resources and highlights the resources that AAEA
19 asserts would be used for replacement energy should an outage occur at IPEC. The last column
20 is an indication of the amount of annual “energy headroom” that was available for all Zone J
21 resources in 2013. AAEA did not assume that any of the other non-highlighted resources in this
22 table would even be available to provide any replacement energy, despite the significant amount
23 of “energy headroom” available for such resources. AAEA also made no assumptions that any
24 new sources of generation or imports would be available.

25

1
2

Table 2. New York City Electric Power Resources – 2013 – AAEA Plants Highlighted

| Units | Summer MW | GWh 2013 | Annual Ave. Capacity Factor based on Summer MW | Remaining Energy Headroom, Annual, GWh |
|--|--------------|---------------|---|---|
| East River CC 1&2 | 288 | 2,465 | 97.9% | 54 |
| NYPA Astoria CC1&2 (2006) | 464 | 3,370 | 82.9% | 697 |
| Brooklyn Navy Yard | 261 | 1,857 | 81.1% | 432 |
| Ravenwood CC 2004 | 218 | 1,471 | 77.0% | 440 |
| Astoria II CC3 and 4 | 544 | 3,084 | 64.8% | 1,678 |
| JFK cogen | 118 | 637 | 61.4% | 401 |
| Astoria East Energy cc1 and cc2 | 555 | 2,796 | 57.5% | 2,068 |
| Linden Cogen (NJ) | 754 | 3,083 | 46.7% | 3,524 |
| East River steam 6&7 Cogen | 322 | 743 | 26.4% | 2,075 |
| NYPA Gowanus/Kent/Pouch GTs | 171 | 343 | 22.9% | 1,151 |
| Arthur Kill 2 steam | 338 | 670 | 22.6% | 2,291 |
| Bayonne Energy Center | 471 | 829 | 20.1% | 3,295 |
| Ravenwood steam 2 | 364 | 620 | 19.4% | 2,571 |
| Astoria 3/5 steam | 754 | 1,065 | 16.1% | 5,541 |
| Arthur Kill 3 steam | 500 | 685 | 15.7% | 3,691 |
| Ravenwood steam 1 | 366 | 427 | 13.3% | 2,777 |
| NYPA Vernon Blvd GTs | 80 | 80 | 11.4% | 620 |
| Ravenwood steam 3 | 964 | 593 | 7.0% | 7,849 |
| NYPA Harlem Rv and Hellgate GTs | 160 | 86 | 6.1% | 1,314 |
| Narrows GTs | 283 | 123 | 5.0% | 2,356 |
| Astoria GTs circa 1970 | 506 | 58 | 1.3% | 4,375 |
| Astoria GT 01 | 15 | 1 | 1.1% | 128 |
| Gowanus GTs | 551 | 54 | 1.1% | 4,772 |
| Ravenwood GT/Jet | 322 | 27 | 1.0% | 2,797 |
| Arthur Kill GT 1 | 12 | 1 | 0.8% | 103 |
| ConEd 59th, 74th, and Hudson Ave GTs | 78 | 2 | 0.2% | 685 |
| Grand Total | 9,458 | 25,169 | 30.4% | 57,684 |
| Excluding AAEA 18A Units | 4,487 | | Annual energy headroom without AAEA 6 plants: | 33,504 |
| Remaining Capacity Not in AAEA Exh 18A | 4,971 | | | |

3
4
5

Source: NY ISO 2014 Gold Book, aggregation by Synapse.

6
7
8
9

Q. Can you please elaborate upon the flaws you observe with AAEA’s approach for determining replacement power sources in the event of an IPEC outage?

10
11

A. As I’ve indicated, AAEA’s approach is highly flawed since it does not abide by principles of economics and transmission, which would determine where power would come

1 from in the event of an outage at IPEC. There is no sound basis to support Mr. McCormick’s
2 arbitrary selection of six units as replacement power sources for an IPEC outage.

3
4 For example, two of the units selected by AAEA – Ravenswood and Astoria Generation – are
5 little-used older units. AAEA has provided no support to indicate that a future-year economic
6 dispatch of New York City in the absence of IPEC output would result in turning to those two
7 particular units and increasing their output in the amounts assumed by AAEA to make up any
8 shortfall. AAEA has not provided any support for an alternative dispatch that would call on
9 those two units in the dramatic amounts that AAEA Exhibit 18D indicates. In fact, given the
10 economics, our modelling did estimate how much those units would be “turned up” under
11 different scenarios. Those results are reported in Table 4 below in this testimony, and the levels
12 of increase are far lower than the AAEA estimate of almost doubling output (AAEA estimated a
13 90% increase in output for those two stations).

14
15 Of further note, AAEA counted all of the 1,912.8 MW of summer capacity at Ravenswood in its
16 tabulation for capacity, yet it included, in its energy summary of 1,297,886 MWH of ozone
17 season energy, only the energy provided by the older Steam units known as Ravenswood 1, 2
18 and 3. The energy output of the 4th Ravenswood unit – a new combined cycle unit – was
19 excluded as “available” for more ozone season production. While this may be because the
20 combined cycle unit was operating at roughly 85% capacity factor for the ozone season (based
21 on EIA 923 data), it too had some “headroom” available in the ozone season that was not
22 considered by AAEA. The newer combined cycle unit at Ravenswood has a much lower NO_x
23 emission rate than the Ravenswood steam units, however, the older steam units were allocated all
24 of the Ravenswood plant generation increase. Thus, in addition to all the concerns I’ve
25 expressed with AAEA’s overall method of replacement power estimation, AAEA has also likely
26 overestimated the contribution of the older, steam-fired, higher-NO_x-emitting portion of
27 Ravenswood and fully discounted the headroom available from the newer, lower-NO_x-emitting
28 portion of the plant – along with discounting headroom from other plants not included by AAEA,
29 as seen in Table 2.

1 In addition, Mr. McCormick’s method is flawed since it did not test the effect of replacement
2 power supply under any scenario where additional resources are added to New York State’s
3 electric power resource base. AAEA used a subset of units available for operation in New York
4 City in 2013 as its starting point, but did not take into consideration any potential new gas-fired
5 resource, either in New York City or in the Lower Hudson Valley. For example, AAEA did not
6 consider the effect if the Champlain Hudson Power Express were to be in place in New York
7 City or assess any shifts in demand-side resources or installation of incremental amounts of solar
8 PV resources. Notably, Mr. McCormick also did not account for the presence of significant
9 amounts of generation in New Jersey, directly connected to the New York system, and available
10 to provide zone J replacement energy. For example, AAEA improperly failed to consider that
11 either the Linden cogeneration plant or the Bayonne Energy Center could provide a portion of
12 replacement energy in the event of an outage at IPEC.

13

14 Moreover, Mr. McCormick’s determinations about replacement power also did not account for
15 the effect of the new, forthcoming Transmission Owner Transmission Solution (TOTS)
16 transmission projects, which will support additional energy flows from upstate and mid-state
17 New York to New York City, and clearly affect which power replacement sources will be called
18 upon to dispatch power to New York City in the event of lost generation from IPEC.

19

20 In sum, Mr. McCormick employed an arbitrary and unsupported methodology to determine
21 replacement resources in the event of an outage at IPEC, which did not respect economics and
22 other critical factors that dictate energy dispatch in New York City.

23

24 **Q. What is the significance of AAEA’s flawed methodology for determining**
25 **replacement power needs and resources with respect to an outage scenario at**
26 **IPEC?**

27

28 A. AAEA’s flawed methodology has resulted in an overestimation of increases in air
29 emissions in New York City in the event of an outage scenario at IPEC. By overstating power
30 replacement needs, focusing on just six plants – two of which are particularly older and dirtier
31 than NYC’s portfolio of resources – and ignoring fundamental economic dispatch principles,

1 AAEA’s analysis results in conclusions about purported additional air pollution that are simply
2 unfounded.

3
4 By way of example and not of limitation, the assignment of a significant amount of replacement
5 energy to Ravenswood and Astoria Generation – little-used older units which have relatively
6 large NO_x emission rates – resulted in the large NO_x increase AAEA estimates in their Exhibit
7 18D.¹⁰ AAEA’s subjective, selective allocation of replacement power to only the older, higher-
8 NO_x emitting steam units as opposed to other, and in some cases newer, resources in zone J
9 results in overstated increases in emissions in NYC.

10

11 **Q. Have you analyzed emissions impacts from New York City plants on a**
12 **unit-specific basis?**

13

14 A. Yes. The aggregate effect of unit-specific dispatch results are shown in the results
15 reported in my direct and rebuttal testimonies. Those effects were shown for an annual period,
16 for different years as presented in my testimonies, and for different resource scenarios. We have
17 subsequently, in response to receiving Exhibit AAEA 18, extracted monthly data from our prior
18 modeling, on a unit-specific basis, for New York City area units to assess ozone season results.
19 Table 3 below shows the NO_x emissions results¹¹ of our modeling for three different scenarios:
20 IPEC in service (base case), IPEC out of service with no changes to energy efficiency and
21 renewable resource deployment (scenario 11), and IPEC out-of-service with higher levels of
22 energy efficiency and renewable resource deployment (scenario 14):

23

¹⁰ Zone J Plant Data of Sufficient Summer Name Plate Capacity to Accommodate Replacement of the Lost IPEC MWH, **AAEA Exhibit 18C**; Estimate of Additional NO_x During May Through September to Replace the 30% of IPEC Power, **AAEA Exhibit 18D**.

¹¹ I focus on NO_x emissions in this testimony, since that is a local pollutant of interest concerning replacement power sources. As noted, and as amply demonstrated in my previous analysis, similar flaws and overestimations exist in relation to AAEA’s CO₂ emissions analysis.

1 **Table 3 – Electric Power Sector Modelled Zone J (NYC) Energy (GWh) and NO_x Emissions for the May –**
 2 **September period for 2015 through 2019**

| | May-Sept. NO _x emissions Zone J units (NYC), tons | | | May - Sept. energy Zone J Units (NYC), GWh | | | GWh Deltas | | NO _x Deltas | | IPEC summer months 2013 GWh | GWh delta -% of IPEC | |
|------|--|------------------------------|------------------------------|--|----------|----------|------------------------------|------------------------------|------------------------------|------------------------------|-----------------------------|----------------------|------------|
| | Scen. 1 IPEC In Service | Scen. 11 IPEC Out of Service | Scen. 14 IPEC Out of Service | Scen. 1 | Scen. 11 | Scen. 14 | Scenario 11 minus scenario 1 | Scenario 14 minus scenario 1 | Scenario 11 minus scenario 1 | Scenario 14 minus scenario 1 | | Sc. 11 - 1 | Sc. 14 - 1 |
| 2015 | 2,209 | 2,209 | 1,719 | 13,587 | 13,587 | 12,436 | - | (1,151) | - | (490) | 7,349 | | |
| 2016 | 2,082 | 2,690 | 2,408 | 13,899 | 15,324 | 14,596 | 1,425 | 697 | 608 | 326 | 7,349 | 9.5% | 8.3% |
| 2017 | 1,710 | 2,252 | 1,964 | 14,062 | 15,644 | 14,852 | 1,582 | 790 | 542 | 254 | 7,349 | 10.8% | 7.4% |
| 2018 | 1,008 | 1,409 | 1,140 | 15,319 | 17,191 | 16,030 | 1,872 | 711 | 400 | 132 | 7,349 | 9.7% | 5.4% |
| 2019 | 978 | 1,354 | 1,065 | 15,366 | 17,170 | 15,903 | 1,804 | 537 | 377 | 87 | 7,349 | 7.3% | 5.1% |

3
 4 Source: Synapse PROSYM modelling, monthly outputs, scenarios 1, 11, 14

5
 6 **Q. Please describe the information in Table 3.**

7
 8 A. The second grouping of columns of Table 3 (“May – Sept. energy Zone J Units (NYC),
 9 GWh”) reports the level of energy output (in gigawatt-hours, or GWh) of the aggregate of NY
 10 ISO zone J (New York City) resources (which include the Linden cogeneration plant and the
 11 Bayonne Energy Center in New Jersey) in each of the May-September periods for 2015 through
 12 2019. This is reported for three scenarios: one with IPEC in service (scenario 1), and two with
 13 IPEC out of service in those months (scenario 11 and scenario 14). As with my previous
 14 testimony, scenario 11 assumes the same baseline assumptions for energy efficiency and
 15 renewable energy deployment in New York State and scenario 14 assumes higher levels of
 16 energy efficiency and renewable resource deployment. The first grouping of columns of Table 3
 17 shows the level of NO_x emissions, in tons, associated with this electric output. Next, in the
 18 column listed as “GWh Deltas” the table shows the level of replacement energy required in zone
 19 J during scenarios with IPEC out of service (scenarios 11 and 14), and in the column listed as
 20 “NO_x Deltas,” the table shows the increase in NO_x emissions associated with this replacement
 21 power. In the last three columns, the table lists May-September 2013 IPEC output,¹² and shows
 22 the “GWH Deltas” as a fraction of this IPEC production.

23
 24

¹² From AAEA’s Exhibit 18B, and checked by Synapse with US EIA form 923 data.

1 **Q. Do your results differ from those of AAEA?**

2
3 A. Yes. As already discussed above, the extracted data as reflected in Table 3 indicates
4 replacement energy amounts much lower than AAEA’s estimate that 30% of IPEC output must
5 be made up by New York City resources. Moreover, the data also shows that NO_x emission
6 levels change over time, and, as seen in my previous testimonies, by 2018 NO_x emissions in
7 New York City are lower than they were in 2015 with IPEC out of service and even without
8 considering scenarios with increases in energy efficiency and renewable energy deployment. In
9 future years, NO_x emissions in NYC in the May-September period with IPEC out of service
10 would continue to be considerably lower than emissions in 2015 with IPEC in service.

11
12 **Q. Have you analyzed emissions impacts from the six generating units**
13 **identified by AAEA as replacement sources in the event of an IPEC outage, in**
14 **comparison to the data reported in AAEA Exhibit 18D?**

15
16 A. Yes. In response to the misleading and inaccurate figures reported in AAEA Exhibit
17 18D, I have generated Table 4 below, which shows Synapse’s modelling results for the six plants
18 identified by AAEA, and for the rest of the zone J units, for the May-September periods for
19 2015, 2017, and 2019. The table lists energy production (in GWH), capacity factors for the
20 plants for the May-September period (“CF”, a measure of “headroom” available), NO_x
21 emissions, and lastly, analogous to results I reported in Table R3 of my previous prefiled written
22 rebuttal testimony, NO_x emission changes for scenarios 11 and 14 relative to the baseline
23 scenario 1, and relative to 2015 emission levels:

24

Table 4 – Unit Specific Output and Emissions in Zone J for May-September period in 2015, 2017, 2019

| MW, Sum | 2015 | Energy Production & CF, May-September, GWh | | | | | | NOx Emissions, Tons, May-September | | | Change in NOX Emissions, %, from Sc. 1 | | Change in NOX Emissions, %, from 2015 | |
|---------|-----------------------------|--|-------|--------|-------|--------|-------|------------------------------------|--------|--------|--|------------|---------------------------------------|------------|
| | | Sc. 1 | CF | Sc. 14 | CF | Sc. 11 | CF | Sc. 1 | Sc. 14 | Sc. 11 | Sc. 14 - 1 | Sc. 11 - 1 | Sc. 14 - 1 | Sc. 11 - 1 |
| 464 | 500 MW CC | 1,333 | 78.7% | 1,240 | 73.2% | 1,333 | 78.7% | 29 | 27 | 29 | -7% | 0% | -7% | 0% |
| 555 | Astoria Energy | 1,750 | 86.4% | 1,704 | 84.1% | 1,750 | 86.4% | 39 | 38 | 39 | -3% | 0% | -3% | 0% |
| 544 | Astoria Energy II | 1,659 | 83.6% | 1,575 | 79.3% | 1,659 | 83.6% | 59 | 56 | 59 | -5% | 0% | -5% | 0% |
| 261 | Brooklyn Navy Yd | 681 | 71.5% | 663 | 69.6% | 681 | 71.5% | 21 | 20 | 21 | -2% | 0% | -2% | 0% |
| 1,694 | Ravenswood Steam | 1,322 | 21.4% | 975 | 15.8% | 1,322 | 21.4% | 488 | 361 | 488 | -26% | 0% | -26% | 0% |
| 389 | Astoria Gen Station (3+GT1) | 366 | 25.8% | 258 | 18.2% | 366 | 25.8% | 162 | 113 | 162 | -30% | 0% | -30% | 0% |
| 5,551 | All Other Zone J Generation | 6,477 | 32.0% | 6,023 | 29.7% | 6,477 | 32.0% | 1,412 | 1,104 | 1,412 | -22% | 0% | -22% | 0% |
| 9,458 | Zone J Total | 13,587 | 39.4% | 12,436 | 36.0% | 13,587 | 39.4% | 2,209 | 1,719 | 2,209 | -22% | 0% | -22% | 0% |
| 3,907 | AAEA Six Plant Total | 7,111 | | 6,414 | | 7,111 | | 797 | 615 | 797 | -23% | 0% | -23% | 0% |
| | 2017 | Sc. 1 | CF | Sc. 14 | CF | Sc. 11 | CF | Sc. 1 | Sc. 14 | Sc. 11 | Sc. 14 - 1 | Sc. 11 - 1 | Sc. 14 - 1 | Sc. 11 - 1 |
| 464 | 500 MW CC | 1,227 | 72.5% | 1,260 | 74.4% | 1,335 | 78.8% | 27 | 27 | 29 | 3% | 9% | -5% | 1% |
| 555 | Astoria Energy | 1,702 | 84.1% | 1,739 | 85.9% | 1,774 | 87.6% | 38 | 39 | 39 | 2% | 4% | -1% | 1% |
| 544 | Astoria Energy II | 1,554 | 78.3% | 1,645 | 82.9% | 1,698 | 85.6% | 55 | 58 | 60 | 6% | 9% | -1% | 2% |
| 261 | Brooklyn Navy Yd | 649 | 68.1% | 634 | 66.6% | 651 | 68.4% | 20 | 19 | 20 | -3% | 1% | -7% | -4% |
| 1,694 | Ravenswood Steam | 1,030 | 16.7% | 1,253 | 20.3% | 1,539 | 24.9% | 382 | 463 | 570 | 21% | 49% | -5% | 17% |
| 389 | Astoria Gen Station (3+GT1) | 274 | 19.3% | 323 | 22.8% | 400 | 28.2% | 114 | 135 | 167 | 18% | 47% | -17% | 3% |
| 5,551 | All Other Zone J Generation | 7,626 | 37.7% | 7,998 | 39.5% | 8,246 | 40.7% | 1,075 | 1,223 | 1,366 | 14% | 27% | -13% | -3% |
| 9,458 | Zone J Total | 14,062 | 40.8% | 14,852 | 43.0% | 15,644 | 45.3% | 1,710 | 1,964 | 2,252 | 15% | 32% | -11% | 2% |
| | AAEA Six Plant Total | 6,436 | | 6,854 | | 7,398 | | 635 | 741 | 886 | 17% | 39% | -7% | 11% |
| | 2019 | Sc. 1 | CF | Sc. 14 | CF | Sc. 11 | CF | Sc. 1 | Sc. 14 | Sc. 11 | Sc. 14 - 1 | Sc. 11 - 1 | Sc. 14 - 1 | Sc. 11 - 1 |
| 464 | 500 MW CC | 830 | 49.0% | 889 | 52.5% | 1,061 | 62.7% | 18 | 19 | 23 | 8% | 29% | -33% | -20% |
| 555 | Astoria Energy | 1,548 | 76.5% | 1,579 | 78.0% | 1,655 | 81.8% | 34 | 35 | 37 | 2% | 7% | -10% | -6% |
| 544 | Astoria Energy II | 1,240 | 62.5% | 1,332 | 67.1% | 1,512 | 76.2% | 44 | 47 | 54 | 8% | 22% | -20% | -9% |
| 261 | Brooklyn Navy Yd | 549 | 57.6% | 554 | 58.2% | 576 | 60.5% | 17 | 17 | 18 | 1% | 5% | -18% | -15% |
| 1,694 | Ravenswood Steam | 447 | 7.2% | 542 | 8.8% | 774 | 12.5% | 167 | 203 | 288 | 22% | 72% | -58% | -41% |
| 389 | Astoria Gen Station (3+GT1) | 106 | 7.5% | 133 | 9.4% | 194 | 13.7% | 44 | 56 | 81 | 25% | 82% | -66% | -50% |
| 5,551 | All Other Zone J Generation | 10,647 | 52.6% | 10,874 | 53.7% | 11,398 | 56.3% | 654 | 688 | 855 | 5% | 31% | -51% | -39% |
| 9,458 | Zone J Total | 15,366 | 44.5% | 15,903 | 46.1% | 17,170 | 49.8% | 978 | 1,065 | 1,354 | 9% | 39% | -52% | -39% |
| | AAEA Six Plant Total | 4,719 | | 5,029 | | 5,772 | | 324 | 377 | 499 | 16% | 54% | -53% | -37% |

Source: Synapse PROSYM modelling, monthly outputs, scenarios 1, 11, 14.

1 **Q. What does Table 4 indicate?**

2
3 A. First, as discussed above, Table 4 indicates that, according to economic dispatch
4 modeling of scenarios without IPEC, increases in generation at the AAEA-identified six plants is
5 much less than AAEA projected in its Exhibit 18D. In particular, generation increases at the
6 Ravenswood steam and Astoria steam plants is limited in all years: for example, in 2017,
7 Ravenswood steam increases its output from 1,030 to 1, 253 GWh in scenario 14, and to 1,539
8 GWh in scenario 11. This increase – of either 223 GWh, or 509 GWh, is far lower than AAEA’s
9 assertion of an increase of 1,168 GWh. Table 4 shows that significant “headroom” exists, and is
10 utilized, at other plants in zone J besides the AAEA-identified six plants.

11
12 Second, the table indicates that during the ozone season, NO_x emissions from zone J plants
13 continue to decline over time. In 2017, NO_x emissions in zone J would range from 11% less, to
14 2% more, than is seen in 2015. In 2019, while NO_x emission levels relative to scenario 1 range
15 from 9% to 39% higher, in both scenarios (11 and 14) absolute NO_x emission levels are
16 dramatically lower than is seen in 2015, prior to any IPEC outage. Notably, the table also shows
17 that NO_x emissions at AAEA’s identified plants are far lower than the 1,353 ton level that
18 Exhibit 18D indicates.

19

20 **Q. Based on your review of Exhibit AAEA 18, do you have an opinion**
21 **regarding AAEA’s conclusion that the unavailability of power from IPEC would**
22 **result in disproportionate air quality impacts on specific environmental**
23 **justice communities?**

24
25 A. This position is unfounded. AAEA’s analysis is flawed as it does not represent
26 technically what will occur under any IPEC May to September outage. AAEA has not showed
27 that specific power plants located in EJ communities will actually increase output,
28 disproportionately relative to other plants, and lead to disproportionate impacts. My analysis
29 shows overall decreases in NO_x emissions over time, and for any periods or scenarios where
30 modelling does show NO_x increases, not only are they temporary, but they also cannot be
31 characterized as disproportionate since resources all over zone J, including in New Jersey and the
32 borough of Staten Island, would be called upon under scenarios where zone J increases are
33 needed. My testimony also demonstrates that AAEA’s assertions significantly exaggerate the
34 zone J output that would be needed under IPEC outage scenarios.

1
2 My testimony herein focuses on the available New York City replacement power sources and the
3 anticipated economic dispatch of those power sources in response to an anticipated need for
4 replacement power which appropriately considers additions of new generating capacity,
5 transmission improvements and demand-side management measures. That analysis has enabled
6 me to highlight AAEA's overestimation of expected NOx emissions resulting from an outage at
7 Indian Point (*see* Table 3 and Table 4). The accompanying sur-rebuttal testimony of
8 Riverkeeper witness John Hinckley further addresses in detail the effect which increased power
9 generation in New York City resulting from outages at Indian Point could reasonably be
10 expected to have on air quality in New York City.

11

12 **Q. Does this conclude your sur-rebuttal testimony?**

13

14 A. Yes.

1 ***Supplemental Bibliography***

2 AAEA Exhibit 1, *Fish Eggs Versus Asthmatic Children in Harlem*

3 AAEA Exhibit 18, “Supplemental Data,” including:

- 4 • AAEA Exhibit 18A: 2012 Form EIA-860 Data – Schedule 3, ‘Generator Data’
5 (Operable Units Only)
- 6 • AAEA Exhibit 18B: EIA-923 Monthly Generation and Fuel Consumption Time
7 Series File, 2013 December, and Indian Point – 2012 Form EIA-860 Data – Schedule
8 3, ‘Generator Data’ (Operable Units Only)
- 9 • AAEA Exhibit 18C: Zone J Plant Data of Sufficient Summer Name Plate Capacity to
10 Accommodate Replacement of the Lost IPEC MWH
- 11 • AAEA Exhibit 18D: Estimate of Additional NO_x During May Through September to
12 Replace the 30% of IPEC Power
- 13 • AAEA Exhibit 18E: Estimate of Additional CO₂ During May Through September to
14 Replace the 30% of IPEC Power

15 EIA Form 923 data for 2013 (provided by AAEA)

16 EIS Form 860 Data for 2012 (provided by AAEA)

17 Emissions & Generation Resource Integrated Database (eGrid) 2010 Generator File (provided by
18 AAEA)

19 Excerpt Spreadsheet, file name: 2012 EIA Form 860 Indian Point 2 and 3, submitted by AAEA
20 on April 22, 2014

21 Excerpt Spreadsheet, file name: 2013 EIA Form 923 Indian Point, submitted by AAEA on April
22 22, 2014

23 Excerpt Spreadsheet, file name: Form 923 6 Plants, submitted by AAEA on April 22, 2014

24 *In the Matter of Entergy Nuclear Indian Point 2, LLC, and Entergy Nuclear Indian Point 3, LLC*
25 *For a SPDES Permit Renewal and Modification (DEC No: 3-5522-00011/00004; SPDES*
26 *No. NY-0004472) and Entergy Nuclear Indian Point 2, LLC, Entergy Nuclear Indian*
27 *Point 3, LLC, and Entergy Nuclear Operations, Inc. Joint Application for CWA § 401*
28 *Water Quality Certification (DEC App. Nos. 3-5522-00011/00030; 3-5522-*
29 *00105/00031), New York State Department of Environmental Conservation Adjudication*
30 *Hearing Transcript (April 17, 2014) at Tr. 9917-10023.*

31 NY ISO, 2014 Loads and Resources “Gold Book” (March 31, 2014), *available at*,
32 [http://www.nyiso.com/public/webdocs/markets_operations/services/planning/Documents](http://www.nyiso.com/public/webdocs/markets_operations/services/planning/Documents_and_Resources/Planning_Data_and_Reference_Docs/Data_and_Reference_Docs/2014_GoldBook_Final.pdf)
33 [_and_Resources/Planning_Data_and_Reference_Docs/Data_and_Reference_Docs/2014](http://www.nyiso.com/public/webdocs/markets_operations/services/planning/Documents_and_Resources/Planning_Data_and_Reference_Docs/Data_and_Reference_Docs/2014_GoldBook_Final.pdf)
34 [GoldBook_Final.pdf](http://www.nyiso.com/public/webdocs/markets_operations/services/planning/Documents_and_Resources/Planning_Data_and_Reference_Docs/Data_and_Reference_Docs/2014_GoldBook_Final.pdf)

35 Synapse, PROSYM Monthly Modelling Outputs, 2014

36 Rebuttal Testimony of John McCormick Regarding Energy and Air Quality Impacts and
37 Environmental Justice Issues Related to Closing Indian Point Energy Center, on behalf of
38 Intervenor African American Environmentalist Association (March 26, 2014)