

Benefit-Cost Analysis for Utility-Facing Grid Modernization Investments

Tim Woolf and Ben Havumaki Synapse Energy Economics

Synapse Webinar March 21, 2019

Webinar logistics



- The webinar is being recorded and will be circulated to all attendees, along with the slides
- All attendees have been muted on entry and will remain muted throughout the webinar
- Please send any questions on the content of the webinar to webinar@synapse-energy.com
- During the Q&A session, the panelists will answer written questions that have been sent to <u>webinar@synapse-</u> <u>energy.com</u>
- Please use the chat feature only to notify the host if you are having a technical issue with the WebEx software or audio

Outline of Presentation

- Presentation is based on draft Berkeley Lab report
- Utility-facing grid modernization concepts
- Grid modernization benefit-cost analysis (BCA) concepts
- Review of recent utility grid modernization plans
 - Focus on BCAs
- How to address key challenges of grid modernization BCAs



Benefit-Cost Analysis for Utility-Facing Grid Modernization Investments

March 2019

Tim Woolf, Ben Havumaki, Divita Bhandari and Melissa Whited, Synapse Energy Economics Lisa Schwartz, Berkeley Lab





Utility-Facing Grid Modernization Concepts

Utility Facing Versus Customer Facing

Grid Modernization

Utility Facing

- Advanced distribution management system (ADMS)
- Geographic information system (GIS)
- Distribution system supervisory control and data acquisition (DSCADA)
- Outage management system (OMS)
- Distributed energy resource management system (DERMS)
- Fault location, isolation, & service restoration (FLISR) a/k/a/ dist. automation
- Volt-var optimization (VVO)
- Advanced metering infrastructure (AMI)
- Network monitoring:
 - Substation devices
 - o Field (feeder) level devices

Customer Facing

- Energy efficiency
- Demand response
- Distributed generation
- Storage
- Electric vehicles
- Advanced meters
- Third-party access
- Customer data
- Cybersecurity







Source: Adapted from World Bank, *Practical Guidance for Defining a Smart Grid Modernization Strategy: The Case of Distribution*, 2017.

March 22, 2019 6



Core (Platform) Components and Applications

	Customer Portal	Customer C	hoice Decision Supp	ort Analytic	s							
		Customer Energy Information & Analytics Out			Outage Information Customer DER Programs			ER Programs	tals	SL		
R ider 'Info	Grid Data Portal	Locational Value Analysis	Dynamic Analysis	Optimi Analy	zation ⁄tics		Market Oversight	Market DER Portfolio Settlement Optimization		ket Por icatio		
Prov Data		Hosting Capacity	Probabilistic Planning	Smart I	Meters	Adva	inced Meters	Volt-var Manageme	ent	DER Management	Appli	
		Power Quality Analysis Fault Analysis		DM	IS		OMS	GIS		Network Model		s
		DER & Load Forecasting	Power Flow Analysis	SCADA			Automated F	ield Devices Advance		Ivanced Protection		oneni
			Operational Data Management						duno			
		Sensing & Measurement						e C				
		Operational Communications (WAN/FAN/NAN)			N)	N)			Cor			
		Physical Grid Infrastructure										

Source: US DOE 2017, Modern Distribution Grid: Decision Guide, Volume III, page 26, Figure 8.



Grid Modernization Benefit-Cost Analysis Concepts



Utility-Facing Grid Modernization Benefits

Benefit	Utility System	Specific Customers	Society
Reduced O&M costs	\checkmark		
Reduced generation capacity costs	\checkmark		
Reduced energy costs	\checkmark		
Reduced T&D costs and losses	\checkmark		
Reduced ancillary services costs	\checkmark		
Increased system reliability	\checkmark		
Increased safety	\checkmark		
Increased resilience	\checkmark	\checkmark	\checkmark
Increased DER integration	\checkmark	\checkmark	
Improved power quality		\checkmark	
Reduced customer outage costs		\checkmark	
Increased customer satisfaction		\checkmark	
Increased customer flexibility and choice		\checkmark	
Environmental benefits			\checkmark
Economic development benefits			\checkmark

Utility-Facing Grid Modernization Costs



Cost	Utility System	Specific Customers	Society
Incremental utility O&M costs	\checkmark	-	-
Incremental utility capital costs	\checkmark	-	-
Incremental T&D costs	\checkmark	-	-
Incremental ancillary service costs	\checkmark	-	-

Utility-facing grid modernization costs are generally recovered from all customers.



Traditional BCA Tests for Energy Efficiency

- The California Standard Practice Manual has been widely used for EE
- Describes five standard cost-effectiveness tests
- Three tests commonly used for EE BCA:
 - <u>Utility Cost test</u>: impacts on the utility system
 - Total Resource Cost test: impacts on utility system and participants
 - Societal Cost test: impacts on society
- These tests are increasingly being used to assess grid modernization, DERs, and related initiatives
- But the CA Manual does not address current needs:
 - Does not address regulatory policy goals
 - Has been interpreted inconsistently
 - Does not address some key DER issues

Source: California Public Utility Commission, Standard Practice Manual, 2001.

Emerging BCA tests for EE: the National Standard Practice Manual



- Designed to update, improve, and replace the California SPM
- Includes a set of fundamental BCA principles
- Identifies the importance of accounting for regulatory goals
- Introduces the "regulatory perspective"
- Articulates that there are multiple options for BCA tests
- Provides a framework for determining a primary BCA test
- Introduces the "Regulatory test"
 - Accounts for a state's regulatory goals
 - Broader than the Utility Cost test
 - Narrower than the Societal Cost test

Source: National Efficiency Screening Project, National Standard Practice Manual (NSPM) for Assessing the Cost-Effectiveness of Energy Efficiency, May 2017



BCA Framework for Grid Mod: US DOE (2 of 2)

DOE report offers three BCA approaches

BCA Approach	Purpose of Expenditure
Least-cost, best-fit	 Traditional distribution expenditures (e.g., replace aging infrastructure) Core, foundational, GM platform components (e.g., SCADA, OMS, GIS)
Utility Cost test	 Non-core, modular components related to enhancing reliability and operational efficiency (e.g., AMI, VVO)
Integrated power system & Societal Cost test	 Non-core, modular components related to enhancing reliability and operational efficiency (e.g., AMI, VVO) Components to achieve regulatory goals and/or societal benefits (e.g., to integrate DERs and enable markets)

Source: Adapted from US DOE 2017, *Modern Distribution Grid: Decision Guide,* Volume III, Section 3.4



Review of Recent Grid Modernization Plans

Review of 21 Recent Grid Mod Plans



Utility	State	Year	Utility	State	Year
National Grid	NY	2016	DTE Energy	MI	2017
NYSEG & RGE	NY	2016	APS	AZ	2016
Unitil	MA	2015	PSE&G	NJ	2018
National Grid	MA	2016	LGE	KY	2018
Eversource	MA	2015	Consumers Energy	MI	2017
Public Service Co.	СО	2016	Central Hudson G&E	NY	2018
SDGE	CA	2016	Hawaiian Electric Cos	HI	2017
Xcel	MN	2017	Southern CA Edison	CA	2016
FirstEnergy	ОН	2017	CT Light & Power	СТ	2010
Vectren	IN	2017	Entergy	AR	2016
National Grid	RI	2018			

Sources: See Lawrence Berkeley National Laboratory, *Benefit-Cost Analysis for Utility-Facing Grid Modernization Investments*, Draft, February 2019.



- Few plans explicitly identify which cost-effectiveness test was used.
- Few plans explicitly identify which discount rate was used.
- Few plans articulate a methodology to account for the interdependencies of grid modernization components.
- Few plans articulate a methodology to account for qualitative benefits.
- Few plans include a robust definition of grid modernization metrics and how they will be used to monitor grid modernization benefits over time.
- Few plans provide both a clear overarching rationale for the investment and an explanation of how components will help meet overall goals.
- Few plans, if any, address customer equity issues directly.



Type and Frequency of Claimed Benefits





Type and Frequency of Monetized Benefits





Grid Modernization Benefit-Cost Ratios





How to Address Key Grid Modernization BCA Challenges

Grid Mod BCA: Key Challenges



- Documenting the purpose of each grid modernization component
- Choosing BCA framework or test
- Choosing a discount rate
- Accounting for interactive effects
- Accounting for qualitative benefits
- Addressing customer equity
 - Some grid modernization components might not reach/serve all customers
 - Some customers might not value some of the grid modernization benefits
- Ensuring net benefits for customers



- Documenting the purpose of each grid modernization component has several important implications for BCA:
- Is the component a traditional distribution investment?
 - May warrant a least-cost, best-fit approach
- Does the component play a core, platform role:
 - May warrant a least-cost, best-fit approach
- Is the component consistent with state regulatory directives and goals?
 - May have implications for the benefits to be considered

Choosing a BCA Test



- Articulate the BCA test upfront
- Apply the least-cost, best-fit framework where warranted
 - Traditional expenditures: replacing aging infrastructure, interconnecting new customers, or maintaining reliability
 - Platform components: necessary to support other, modular components
 - The validity of this test rests upon justification of the type of expenditure
- Apply multiple cost-effectiveness tests
 - Utility Cost test: best indication of impacts on customer bills
 - Regulatory test: best indication of achieving regulatory goals
- Apply both approaches as a check
 - For components where the least-cost, best-fit approach is used, apply the Utility Cost test to check the impact on costs.

Accounting for Interdependences



- Apply the least-cost, best-fit framework where warranted
 - Platform components
 - The validity of this test rests upon justification of the type of expenditure.
- Apply BCA tests for every component in isolation
 - Utility Cost test
 - Regulatory test
- Apply BCA tests to several scenarios where components are bundled in different ways.
 - Just platform components
 - Layers of modular, application components on top of platform



Accounting for Interdependences: Example

	Scenario 1: Platform Components Only	Scenario 2: Platform Plus FLISR and VVO	Scenario 3: Scenario 2 Plus AMI and DERMS	
Costs (Mil PV\$)	24	28	32	
Benefits (Mil PV\$)	22	36	38	
Net Benefits (Mil PV\$)	-2	8	6	
Benefit-Cost Ratio	0.9	1.3	1.2	
Findings:	not cost-effective	cost-effective	potentially cost-effective	

Scenario 3 has two potential interpretations:

- AMI and VVO are deemed cost-effective, because the portfolio is cost-effective.
- AMI and VVO are deemed not cost-effective, because they reduce the net benefits relative to scenario 2.



- Put as many benefits as possible in monetary terms
- Apply the least-cost, best-fit framework where warranted
 - This approach does not require monetization of benefits
 - It requires only a minimization of costs, for the desired function/outcome
 - The validity of this test rests upon justification of the type of expenditure
- Establish metrics to assess benefits
 - Metrics do not need to be in monetary terms
- Use quantitative methods to address qualitative benefits:
 - use a point system to assign value to qualitative benefits
 - use a weighting system to assign priorities to qualitative benefits
 - assign proxy values for significant qualitative benefits
 - use multi-attribute decision-making techniques



Accounting for Qualitative Benefits: Example

	Scenario 1: Platform Components Only	Scenario 2: Platform Plus FLISR and VVO	Scenario 3: Scenario 2 Plus AMI and DERMS
Monetary Impacts:			
Costs (Mil PV\$)	24	28	32
Benefits (Mil PV\$)	22	36	38
Net Benefits (Mil PV\$)	-2	8	6
Benefit-Cost Ratio	0.9	1.3	1.2
Qualitative Impacts:			
Resilience	1	1	3
Customer choice& flexibility	1	2	3
Findings:	not cost-effective	cost-effective	cost-effective

Scenario 3 is deemed to be cost-effective because of the high value of qualitative benefits.

Addressing Customer Equity



- Fully document the purpose and role of each grid modernization component
 - Traditional
 - Platform
 - Least-cost, best-fit
- Articulate the beneficiaries of grid modernization components
 - Which customers
 - How many customers
 - Over what time period
- Prioritize the results of the Utility Cost test over other tests
 - Utility Cost test provides the best indication of impacts on customer bills
- Conduct a long-term bill impact analysis
 - Helps to put the grid modernization costs in context



Regulators can use ratemaking and cost recovery approaches to help ensure that customers experience net benefits from grid modernization proposals.

- Limit the amount of grid modernization costs that the utility can recover to those proposed in the grid modernization plan
 - With allowance for contingency
- Limit the amount of grid modernization costs that the utility can recover to achievement of grid modernization benefits
 - Metrics can be used to assess achievement of benefits.



Summary: How to Address Key Challenges

Challenge	Potential Approaches
Documenting the purpose of each grid modernization component	Specify a standard taxonomy for grid modernizationDefine purpose and role of grid modernization components
Choosing BCA framework	 Articulate the BCA framework upfront Focus on two tests: Utility Cost test and Regulatory test Use the least-cost, best-fit approach where warranted
Choosing discount rate	 Choose a discount rate that reflects state regulatory goals Conduct sensitivities using different discount rates
Accounting for interactive effects	 Use the least-cost, best-fit approach where warranted Use scenarios with different combinations of components Conduct BCA for grid modernization components in isolation
Accounting for qualitative benefits	 Use the least-cost, best-fit approach where warranted Establish metrics to assess the extent of benefits Apply methodologies to make qualitative benefits transparent
Addressing customer equity	 Give more weight to the Utility Cost test Document beneficiaries Estimate long-term bill impacts
Ensuring net benefits for customers	 Limit cost recovery to the proposed costs in grid modernization plans Limit cost recovery to achievement of proposed benefits Establish metrics to monitor achievement of benefits



Synapse Energy Economics is a research and consulting firm specializing in technical analyses of energy, economic, and environmental topics. Since 1996 Synapse been a leader in providing rigorous analysis of the electric power and natural gas sectors for public interest and governmental clients.

Tim Woolf Senior Vice-President Synapse Energy Economics 617-453-7031 twoolf@synapse-energy.com

www.synapse-energy.com



Send your questions to webinar@synapse-energy.com



Additional Slides

March 22, 2019 33



- 1. Utility seeking review of costs before spending
 - Typically in a case dedicated to review of proposed investments
 - Utility often asks for regulatory guidance or approval
 - Allows for focused review of proposal
 - Utility can be held accountable to cost forecasts
 - Costs can be reduced or rejected before incurred
- 2. Utility seeking recovery of costs after spending
 - Typically in a rate case
 - Allows for review in context of other costs
 - Grid modernization issues might be one of many contentious issues
 - Difficult to modify, reduce, or disallow costs after they are spent
- Most grid modernization plans are submitted prior to spending

BCA Principles



Principle	NSPM	DOE	NYPSC
Assess projects comparably with traditional resources or technologies	\checkmark	\checkmark	Y
Account for state regulatory and policy goals	\checkmark	\checkmark	
Account for all relevant costs and benefits, including hard-to-monetize	\checkmark	\checkmark	
Ensure symmetry across relevant costs and benefits	\checkmark	\checkmark	
Apply full life-cycle analysis	\checkmark	\checkmark	\checkmark
Apply incremental, forward-looking analysis	\checkmark	\checkmark	
Ensure transparency	\checkmark	\checkmark	✓
Avoid combining or conflating different costs and benefits			\checkmark
Assess bundles and portfolios instead of separate measures	\checkmark	\checkmark	
Address locational and temporal values		\checkmark	\checkmark

Sources: National Efficiency Screening Project, National Standard Practice Manual, 2017; US DOE, Modern Distribution Grid: Decision Guide, Volume III, 2017; New York Public Service Commission, Order Establishing the Benefit-Cost Framework, 2016.



- The term "benefit-cost analysis" typically refers to an approach that puts all costs and benefits into monetary values.
 - If benefits exceed costs, the investment is deemed to be cost-effective.
- The term "business case" typically refers to an approach that is broader and more flexible than a BCA.
 - A business case allows utilities to account for impacts that are not monetized.
 - Some business case approaches monetize all costs and benefits, but then leave flexibility for considering qualitative factors.
 - Other business case approaches include little monetization of the benefits, relying almost entirely on qualitative grounds for justifying the investment.
- Regardless of what the approach is called:
 - Monetary values should be used as much as possible.
 - Qualitative impacts should be fully documented and accounted for.

Choosing a Discount Rate

- ► The discount rate reflects a particular "time preference."
 - The relative importance of short- versus long-term impacts
- Examples of discount rates
 - Investor-owned utility WACC: 5%-8%
 - Publicly-owned utility WACC:
 - Utility customers:
 - Low risk:
 - Societal:

Varies widely

3%-5%

0%-3%

<0%-3%

 Utility weighted average cost of capital (WACC) is widely used in BCA for grid modernization and other purposes.





The goal of BCAs for unregulated businesses is different from the goal of BCAs in regulatory settings:

- For <u>unregulated</u> businesses, the goal of BCA is to maximize shareholder value.
 - Investors' time preference is driven entirely by investors' opportunity cost and risk, and the WACC reflects both of those.
- ► For <u>regulated</u> utilities, the goal of BCA is fundamentally different:
 - The goal is to provide safe, reliable, low-cost power to customers and meet policy goals.
 - The goal is not to maximize shareholder value.
- Since the goal for a regulated utility is different, the time preference is also different. Thus, the choice of a discount rate should take this into consideration.

Discount Rate Considerations



- ► The choice of discount rate is a policy decision.
- The discount rate should reflect the time preference chosen by regulators on behalf of all customers, i.e., the regulatory perspective.
- The regulatory perspective should account for many factors:
 - low-cost, safe, reliable service; intergenerational equity; other regulatory policy goals
- The regulatory perspective suggests a greater emphasis on long-term impacts than what is reflected in the WACC.
 - Which implies a lower discount rate
- Grid mod plans can use sensitivities to consider different discount rates.
 - Use the utility WACC as a high case
 - Use a low-risk or societal discount rate as a low case