
Nova Scotia Utility and Review Board

IN THE MATTER OF *The Public Utilities Act*, R.S.N.S. 1989, c.380, as amended

M11539

**Evidence of Board Counsel Consultant Robert
Fagan, Synapse Energy Economics**

**Nova Scotia Power Incorporated
Battery Energy Storage System (BESS) Project
Capital Cost Approval Application**

April 4, 2024

NON-CONFIDENTIAL

1 **Introduction and Qualifications**

2 **Q Please state your name and occupation.**

3 **A** My name is Bob Fagan. I am a Vice President at Synapse Energy Economics, Inc.
4 (“Synapse”). My business address is 485 Massachusetts Avenue, Suite 3, Cambridge,
5 Massachusetts 02139.

6 **Q Please describe Synapse Energy Economics.**

7 **A** Synapse is a research and consulting firm specializing in energy and environmental
8 issues, including electric generation, transmission and distribution system reliability,
9 ratemaking and rate design, electric industry restructuring and market power,
10 electricity market prices, stranded costs, efficiency, renewable energy, environmental
11 quality, and nuclear power.

12 Synapse’s clients include state consumer advocates, public utilities commission staff,
13 attorneys general, environmental organizations, federal government agencies, and
14 utilities. Synapse also occasionally works on behalf of certain clean energy providers.

15 **Q Please summarize your work experience and educational background.**

16 **A** I have worked at Synapse for over 19 years, beginning as a Senior Associate and
17 rising to my current position as Vice President. I am a mechanical engineer by
18 training, with a BS degree from Clarkson University (then Clarkson College) and an
19 MA in Energy and Environmental Studies from Boston University. I have worked in
20 or adjacent to the electricity industry for over 35 years, the last 30 years in a
21 consulting capacity. My work focuses primarily on examining the technical and
22 regulatory aspects of electric utility industry resource planning and related matters.

1 I have worked on behalf of the Nova Scotia Utility and Review Board Counsel on
2 numerous occasions since 2005, when I first addressed open access transmission tariff
3 (OATT) issues in Nova Scotia Power's (NS Power's) original filing of its OATT. In
4 the intervening years I have worked on energy efficiency, resource planning,
5 Maritime Link and other matters in different proceedings before the Nova Scotia
6 Utility and Review Board.

7 A copy of my current resume is provided as Exhibit 1.

8 **Q On whose behalf are you testifying in this case?**

9 **A** I am testifying on behalf of Board Counsel, for the Nova Scotia Utility and Review
10 Board.

11 **Q Have you testified previously before the Utility and Review Board?**

12 **A** Yes. I have testified on behalf of Board Counsel in several proceedings and
13 participated in Integrated Resource Plan proceedings in Nova Scotia numerous times
14 over the past two decades, beginning in 2005.

15 **Q What is the structure of your testimony?**

16 **A** After this introductory section, I state the purpose of my testimony and summarize
17 my findings. I then examine each of six issue areas, including Directives from the
18 Electricity Act, Consistency/Alignment with the IRP and the Clean Power Plan,
19 Performance/Functionality, Project Costs, Depreciation/Sustainability, and Contract
20 Structure/Procurement Process. I review NS Power's Application and how they
21 address each issue. Lastly, I provide specific recommendations to the NS UARB on
22 the BESS Capital Application.

1 **Purpose and Summary Findings**

2 **Q What is the Capital Cost Approval Application?**

3 **A** NS Power's Application describes its planned process and technical elements for the
4 battery energy storage system (BESS) installation, which consists of three sites each
5 hosting a 50 MW BESS. It also describes the costs, available incentives from the
6 Canadian government's Smart Renewables and Electrification Pathways (SREP)
7 program, and low interest financing available for a portion of the project through the
8 Canada Infrastructure Bank (CIB).

9 **Q What is the purpose of your testimony in this proceeding?**

10 **A** The purpose of my testimony is to address NS Power's request for approval of
11 expenditures to deploy the battery energy storage project described in the Capital
12 Cost Approval Application ("Application"). I examine the major issue areas in NS
13 Power's Application, with a particular focus on i) the alignment of the proposed
14 project with the resource plans evaluated by NS Power in the Evergreen IRP
15 proceedings and Nova Scotia's Clean Power Plan, ii) a review of the underlying gross
16 costs and costs net of Canadian government programs that allow for reduced revenue
17 requirements from NS Power ratepayers, and iii) the planned operation of the project
18 and how it supports Nova Scotia's 2030 Clean Power Plan, in particular the need to
19 integrate increasing amounts of renewable energy onto the grid, while phasing out the
20 use of coal for electricity production by 2030.

21 **Q What are your summary findings?**

22 **A** I find that NS Power's BESS project is supportive of Nova Scotia's 2030 Clean
23 Power Plan resource pathway, is in alignment with the preferred portfolio of NS

1 Power's most recent Evergreen IRP update, and the project's completion is in the best
2 interest of Nova Scotia Power ratepayers.

3 **Directives from the Electricity Act Regulation**

4 **Q What are the prescribed battery energy storage requirements imposed on**
5 **Nova Scotia Power associated with regulations under Section 4D of**
6 **Electricity Act?¹**

7 **A** Under Section 4D (9) of the Electricity Act, the Governor in Council can prescribe
8 regulations concerning battery storage:

9 (9) The Governor in Council may make regulations respecting any aspect of an energy-
10 storage project or an energy-storage agreement under this Section, including

11 (a) prescribing the eligible project, including structures, equipment, controls or other
12 components of a project;

13 (b) the time frame for entering into an agreement to purchase the output from a
14 project;

15 (ba) prescribing a project under subsection (2A);

16 (bb) prescribing project terms and conditions under subsection (4A);

17 (c) obligations for data collection related to the use of the service, operations and
18 economics of a project, and the format in which this information is to be provided to
19 the Minister;

20 (d) the minimum and maximum term for an agreement;

¹ *Electricity Act*. 2004, c. 25, s. 1.

1 (e) any other matter the Governor in Council considers necessary or advisable for the
2 proper administration of the program.

3 The Governor in Council has prescribed energy storage regulations under section 4D of
4 the Electricity Act,² on December 21, 2023, as follows:

5 **Prescribed energy-storage projects under Section 4D of Act**

- 6 **3 (1)** The Nova Scotia Power Incorporated lithium-ion battery storage project is
7 prescribed as an energy-storage project under Section 4D of the Act.
8
9 **(2)** Nova Scotia Power Incorporated must install three 50 MW 4-hour duration
10 lithium-ion grid-scale batteries with an electricity storage energy rating of 200 MWh
11 each.
12
13 **(3)** Each 50 MW battery must be housed in a separate facility.
14
15 **(4)** Nova Scotia Power Incorporated must install a facility adjacent to the
16 substation in all of the following locations:
17
18 (a) Bridgewater, Lunenburg County;
19
20 (b) Canaan Road substation on White Rock Road, Kings County;
21
22 (c) Spider Lake, Halifax County.
23
24 **(5)** Nova Scotia Power Incorporated must prepare and file with the Board and
25 the Minister an annual report for each year up to and including the year
26 2030, on the use of each battery project, including details about the
27 services provided.

² Prescribed Energy-Storage Projects Regulations made under subsection 4D(9) of the *Electricity Act* S.N.S. 2004, c. 25 O.I.C. 2023-365 (effective December 21, 2023), N.S. Reg. 250/2023. Cited from <https://novascotia.ca/just/regulations/regs/elecpcsp.htm>.

1 **Q Is it your understanding that NS Power’s Battery Energy Storage System**
2 **Project in this Capital Cost Approval Application is the prescribed energy**
3 **storage project under the Electricity Act regulation?**

4 **A** Yes. The Capital Application reflects the planned installation of three specifically
5 sited battery energy storage resources, whose initial installed capacity matches the
6 requirement in the regulation. The project scope information was conveyed by NS
7 Power to the Nova Scotia government, resulting in the specifics reflected in the
8 regulation.³

9 **Q What is your understanding of the ways in which this Application for review**
10 **before the NS UARB is different from other applications for capital**
11 **expenditures?**

12 **A** It is my understanding that the Electricity Act regulation requiring NS Power to
13 install certain amounts and types of a resource, at identified locations, is a highly
14 specific regulation, and is not usual. It removes from NS Power the discretion to
15 further consider (in this Application) the types, amount, and location of electric
16 system resources that it seeks cost recovery approval from the NS UARB. However,
17 it is notable that the specifics of the project itself were provided to the government, by
18 NS Power; and it is also notable that the specific attributes of the project are in
19 alignment with the preferred portfolio of resources of NS Power’s most recent update
20 to its Integrated Resource Plan, as I further describe here.

21

³ NS Power Response to Consumer Advocate IR-1, “NS Power provided the government with its view on the optimal BESS Project scope and configuration, which is as reflected in the application.”

1 **Consistency / Alignment with IRP and Clean Power Plan**

2 **Q How does the planned installation of NS Power’s BESS project particulars,**
3 **including all three sites, compare to NS Power’s resource plan from its most**
4 **recent integrated resource plan (IRP) update?**

5 **A** The 150 MW of BESS capacity in the Application represents a portion of the total
6 BESS capacity indicated in the preferred portfolio from the IRP update, and its
7 planned installation dates are within the timelines required for BESS resource
8 implementation as indicated in the resource plan.

9 The 2023 Evergreen IRP update results were submitted by NS Power in M11307 on
10 October 17, 2023, in its Reply Submission. NS Power stated the following at page 5:

11 NS Power’s current planning does not anticipate that the Atlantic Loop will be available
12 by 2030. As demonstrated in the 2023 10 Year System Outlook report, the Company’s
13 central planning case is consistent with Evergreen IRP scenario CE1-E1-R2, which does
14 not include the Atlantic Loop. **Using scenario CE1-E1-R2 as the basis for system**
15 **planning** allows NS Power to act on investments corresponding to the updated Evergreen
16 IRP Action Plan and 2030 Resource Development Plan (Figure 9 of the Evergreen IRP
17 Update) to meet 2030 decarbonization targets, and leaves open the ability to further study
18 various regional integration opportunities post-2030. [**emphasis added**]

1 **Q What resources are contained in Evergreen IRP Scenario CE1-E1-R2, for**
 2 **the next decade?**

3 **A** The table below, from NS Power’s data tables available on their IRP website,⁴
 4 indicates the resource mix from Scenario CE1-E1-R2, from 2025 through 2035.⁵

5 **Scenario CE1-E1-R2 Nameplate Capacity of Supply Resources**

Generator	2025	2026	2027	2028	2029	2030	2031	2032	2033	2034	2035
Existing Coal Retirements	0	0	0	1 Units	3 Units	3 Units	0	0	0	0	0
Existing Gas Retirements	0	0	0	0	0	0	0	0	0	0	0
Gas - New CTs & Recips	0	0	0	150	450	450	450	470	620	620	770
Gas - Conversion	0	0	0	0	150	150	150	150	150	150	150
Diesel CTs	231	231	231	231	231	231	231	231	231	231	231
Domestic Hydro	374	374	374	374	374	374	374	374	374	374	374
Tidal	9	9	9	9	9	9	9	9	9	9	9
Biomass	75	75	75	75	75	75	75	75	75	75	75
Wind	919	1297	1497	1697	1897	2097	2297	2497	2697	2844	2994
Solar	203	203	202	202	203	203	203	203	202	202	203
Maritime Link Blocks	153	153	153	153	153	153	153	153	153	153	153
Synchronous Condensers	0	30	40	90	140	140	200	200	200	200	200
Firm Imports	0	0	0	0	0	0	0	0	0	0	0
Nuclear	0	0	0	0	0	0	0	0	0	0	0
HFO - Conversion	0	0	0	0	0	459	459	459	459	459	459
Hydrogen	0	0	0	0	0	0	0	0	0	0	0
Geothermal	0	0	0	0	0	0	0	0	0	0	0
Battery 4H	0	30	40	90	140	140	200	200	200	200	200

6
 7 *NS Power Evergreen IRP results, 2023, Scenario CE1-E1-R2.*

8 The resource mix seen in the above table includes 4-hour battery energy storage
 9 resources (cumulative) of 40 MW in 2027, 90 MW in 2028, 140 MW in 2029 and
 10 2030, and 200 MW in the years from 2031 through 2035. The full table includes 200
 11 MW of 4-hour battery storage resources through 2048, and then increases the battery
 12 resource to 320 MW in 2049, and 400 MW in 2050 (the last year of the IRP analysis).

⁴ <https://irp.nspower.ca/files/key-documents/annual-evergreen-materials/evergreen-IRP-Final-Modeling-Results-Data-Tables-2023.xlsx>

⁵ Scenario CE1-E1-R2 nomenclature means earlier year (2035) achievement of net zero carbon emissions (CE1), vs. 2050 achievement (CE2); current policy (i.e., higher peak impacts) of electrification trends, E1, vs. lower peak impacts with a “hybrid peak” mitigation scenario (E2); and R2 is “no Atlantic Loop”, vs. R1 which would include the Atlantic Loop as an alternative/supplemental source for renewable energy from Quebec.

NS Power’s application for these three BESS projects envisions a 2025 completion for the first two projects (100 MW), and a 2026 completion for the third project. While this is an accelerated installation compared to the specific modeling results from Scenario CE1-E1-R2, the Evergreen IRP results illustrated a range of “optimal” pacing for battery energy storage system deployment under different sensitivities. For example, under the scenario with a higher level of distributed resources (e.g., solar PV), and no Atlantic Loop, the IRP modeling calls for the highest level of battery resource installation, at a pace requiring more than 500 MW of BESS resources by 2030 (Scenario CE1-E1-R2-HDER). Other sensitivities show increased or decreased pacing and total magnitude of battery installation, as shown in the table below.

Battery Resource Nameplate Capacity by Scenario

Scenario	2025	2026	2027	2028	2029	2030	2031	2035	2050
CE1-E1-R1	40	90	100	100	100	100	100	100	370
CE1-E1-R1 AAT	0	30	30	50	100	100	140	140	230
CE1-E1-R1 BD	0	10	10	20	70	70	160	170	200
CE1-E1-R1 BPDSM	0	20	50	50	100	100	100	100	210
CE1-E1-R1 DACC	0	170	170	170	170	170	170	170	200
CE1-E1-R1 DH	0	80	120	120	120	120	120	120	840
CE1-E1-R1 HDER	0	40	80	120	120	120	120	120	1,280
CE1-E1-R1 HFPP	0	20	30	30	30	30	30	30	310
CE1-E1-R1 LFPP	0	0	0	10	30	30	30	30	200
CE1-E1-R1 MMDSM	0	20	30	30	40	40	70	70	240
CE1-E1-R1 WI	0	100	100	100	100	100	100	100	270
CE1-E1-R2	0	30	40	90	140	140	200	200	400
CE1-E1-R2 DACC	0	30	40	110	110	110	200	200	360
CE1-E1-R2 DH	0	60	80	100	160	160	200	200	430
CE1-E1-R2 HDER	0	120	160	240	440	560	800	800	1,720
CE1-E1-R2 MMDSM	10	20	30	30	30	30	200	200	430
CE1-E2-R2	0	50	100	100	130	130	200	200	330
CE1-E2-R2 HBHR	0	0	0	0	0	0	0	0	240
CE1-E2-R2 MMDSM	0	0	0	0	110	110	200	200	230
CE1-E3-R1	0	10	10	10	10	10	100	100	230
CE1-E3-R2	0	0	0	10	100	100	200	200	430
CE2-E1-R1	0	0	0	0	10	10	30	30	430
CE2-E1-R2	0	30	40	60	110	110	200	200	390
CE2-E1-R2 DH	0	0	10	20	30	140	200	200	430

Synapse, compilation based on NS Power Evergreen IRP nameplate capacity results for battery resources.

1 Roughly half of the scenarios included the Atlantic Loop as a resource, with capacity
2 and energy sourced from Quebec and with the costs of a new transmission line to
3 Quebec included in the results. The other half of the scenarios did not include the
4 Atlantic Loop, and instead of renewable energy from Quebec, the scenarios included
5 significant increases in wind energy from onshore resources in Nova Scotia. Synapse
6 provided comments on NS Power's Evergreen IRP results in M11307,⁶ which include
7 the summary information on the resource quantities by scenario seen in the tables
8 above.

9 **Q What is the currently planned resource deployment path in Nova Scotia's**
10 **Clean Power Plan?**

11 **A** The resource deployment path of Nova Scotia's Clean Power Plan includes more than
12 1,000 MW of additional wind power resources by 2030, expected large scale solar
13 resources of at least 300 MW, small scale solar resources through the Commercial
14 Net Metering Program and the Community Solar program, 300-400 MW of battery
15 energy storage resources, a new Reliability Tie transmission line to New Brunswick,
16 fast-acting generation resources, emergency and reliability backup through oil and
17 gas conversions at coal plants, and electrification and demand management (to reduce
18 peak load growth).⁷

⁶ Synapse Comments on Nova Scotia Power Updated Action Plan and Roadmap (August 2023).
<https://uarb.novascotia.ca/fmi/webd/UARB15>, Matter 11307, Exhibit N-3, August 8, 2023.

⁷ Nova Scotia's 2030 Clean Power Plan, a presentation by the Nova Scotia Department of Natural Resources and Renewables, <https://beta.novascotia.ca/sites/default/files/documents/1-3582/nova-scotia-clean-power-plan-presentation-en.pdf>. Slide 21.

1 **Q Do the three NS Power BESS projects in this Capital Application align with**
2 **Nova Scotia Power’s most recent IRP results?**

3 **A** Yes. While the exact pacing of the installations is slightly different than the modeling
4 results, the underlying substance of the IRP result is directly supported by the BESS
5 project.

6 **Q Do the three NS Power BESS projects in this Capital Application align with**
7 **Nova Scotia’s underlying Clean Power Plan?**

8 **A** Yes, they form a subset of required resources. NS Power presented a report in
9 compliance with the NS UARB’s directive in M11017, *The Path to 2030*,⁸ which
10 contains a listing of its expected Clean Power Plan Resources (Figure 1, page 6),
11 including the 150 MW of BESS from this Capital Application deployed in 2025-
12 2026, in addition to another 250 MW of energy storage resources under Provincial
13 Section 4D and 4D Projects for implementation between 2026 and 2028.

14 **Performance and Functionality**

15 **Q What the core functional attributes of the BESS projects in this Capital**
16 **Application?**

17 **A** The core functionalities - all of which are highly critical to support the Provincial
18 transition to increased amounts of renewable energy and closure of coal-fired
19 generation plants - are specifically described in the Application’s Appendix C

⁸ NS Power’s report *The Path to 2030* is available on the NS UARB site under M11017, but is also directly available here <https://www.halifaxexaminer.ca/wp-content/uploads/2023/12/92447.pdf>.

1 (redacted version).⁹ They include the following five resource attributes, taken
2 verbatim from the Appendix:

3 **1. Dispatchable firm capacity:** The BESS can provide reliable capacity for a continuous
4 duration of 4 hours at full output to meet peak system demand. The proposed BESS
5 would store 600 MWh of energy, enabling up to 4 hours of continuous output at 150 MW
6 (or longer durations at lower output levels; i.e. 50 MW for 12 hours, or myriad additional
7 capacity/duration combinations) for inclusion in the generation dispatch schedule
8 between recharge cycles.

9 **2. Energy time shifting, or “arbitrage”:** The BESS will allow NS Power to store low-
10 cost energy purchased and generated off-peak and utilize that to displace energy that
11 would otherwise be generated or purchased during higher cost on-peak periods. NS
12 Power’s typical operation would charge the BESS during high wind/low load situations
13 (predominantly overnight) and economically dispatch the BESS during high load/low
14 wind situations (predominantly evening or morning peaks). This functionality directly
15 enhances the value of intermittent renewable resources by converting their intermittency
16 to high value period dispatchability.

17 **3. Grid frequency and voltage support:** The BESS will be able to sense and respond to
18 fluctuations in system frequency to mitigate system-level frequency spikes or dips
19 because of changes in generation or load and thus maintain grid stability to ensure
20 reliable and continuous flow of electricity across the grid. The BESS can also provide
21 system voltage support by adjusting reactive power production or absorption in order to
22 meet local system requirements and respond to disruptions in other areas of the grid. The
23 BESS can provide this support automatically, supporting typical grid voltage and
24 frequency fluctuations or correcting for an atypical event such as loss of a generation
25 source or loss of a significant load.

⁹ NS Power, BESS Project Capital Cost Approval Appendix C, pages 2-3.

1 **4. Grid flexibility through response to controlled set points:** The NS Power System
2 Operator will determine set points for active and reactive power levels which the BESS
3 will then be able to automatically respond to, instantaneously offsetting increases and
4 decreases in customer load and resulting changes in system current and voltage. The main
5 objective of such “P/Q” (i.e. active power and reactive power) set points is to balance the
6 system generation and load keeping the system frequency within the limits prescribed by
7 the ECC.

8 **5. Spinning reserve:** Spinning reserve is generation capacity that is online, synchronized
9 to the grid and able to respond quickly to sudden changes in load or unexpected events,
10 such as an unplanned generation outage. The proposed BESS will provide nearly
11 instantaneous response by being able to immediately inject power onto the grid during
12 such an event, and without any associated fuel (including carbon) costs. This service can
13 be provided whenever the BESS is producing energy below its maximum capacity,
14 including when idle or charging.

15 **Q Why are these core functionalities critically important?**

16 **A** Battery energy storage system projects are often considered primarily as a means to
17 store energy when production is less expensive (or renewable-based) and make it
18 available at other times, especially during peak periods. This is directly reflected in
19 the second attribute above.

20 However, the other attributes noted by NS Power in the Appendix reflect a combined
21 multi-functional grid support capability that provides nearly instantaneous response
22 for both day-to-day “normal” and less-frequent contingency events (regular, and
23 extreme), in support of core frequency, voltage, and load following requirements –
24 often in a fully automated mode, but also amenable to manual dispatch if or as
25 required by NS Power. These combined capabilities render the resource highly
26 valuable for supporting reliability, while simultaneously allowing it to displace the

1 use of older, less efficient, dirtier, and often costlier resources that currently provide
2 the functionality noted.

3 While 150 MW in total is not sufficient to fully displace the use of other, older supply
4 assets to provide these functions, NS Power is likely to learn invaluable lessons
5 associated with this first 150 MW tranche. As more BESS resources are made
6 available, provision of ancillary service functionality can continue to transition to
7 those resources as appropriate, and NS Power can directly support not only the new
8 renewable energy assets interconnecting to the grid but can relax the need to sustain
9 older, less efficient, lower performing¹⁰ (and likely costlier) resources.

10 **Q Is the grid-forming functionality of the BESS resources important?**

11 **A** Yes. As noted in NS Power’s response to information requests, the grid-forming
12 capabilities complement the other attributes provided by the BESS resources. Grid-
13 forming capabilities are noted by NERC to be “a relatively low-cost solution that
14 helps ensure system-wide stability...” and NERC recommends “...implementing
15 [grid forming capability] for all new [bulk power system] connected BESS...to
16 mitigate any potential [bulk power system] reliability risks that could be posed under
17 high IBR [inverter-based resources] penetration levels expected in the near future”.¹¹

18 **Project Costs**

¹⁰ The near instantaneous response rate of utility-scale BESS resources surpasses the response rate of some of the other resources currently used to provide these functionalities.

¹¹ NS Power response to Synapse IR-4, page 3, quoting from a NERC (North American Electric Reliability Corporation) September 2023 *White Paper: Grid Forming Functional Specifications for BPS-Connected Battery Energy Storage Systems*, included as Attachment 1 to the IR response.

1 **Q How did you review the overall project costs associated with the NS Power**
2 **BESS project?**

3 **A** We reviewed the Application itself, and responses to information requests, including
4 review of the response to NS UARB request IR-11, confidential Attachment 1.
5 Attachment 1 to that response is the NS Power Grid Battery Revenue Requirement
6 model and contains detailed quantitative information on the projected costs and
7 projected revenue requirements for the project. Our review of the revenue
8 requirement model was undertaken to reconcile at a high level how the key cost
9 parameters listed and explained in the Application were treated in the revenue
10 requirement formulation. While NS Power did not estimate a rate impact associated
11 with the BESS project, they did use a revenue requirements model to “evaluate
12 customer benefit.”¹²

13 **Q What is the cost of the BESS project?**

14 **A** NS Power states that the forecasted gross capital cost of the BESS project is \$354
15 million, for all three sites.¹³ The net cost, after factoring in the SREP program funding
16 of \$111 million is \$243 million, inclusive of AFUDC.¹⁴ For 150 MW, this equates to
17 a gross per unit cost of \$2,360 per MW (\$CA) for a 4-hour duration battery energy
18 storage system. In US currency denominations, at an exchange rate of 1.35 Canadian
19 to US dollars,¹⁵ the gross cost is \$1,748 per MW (in \$2024). In real 2023 currency,
20 the gross cost is roughly \$1,696/MW (\$US), which is seen in the graph that follows.

¹² NS Power response to Synapse IR-1 (c).


¹³ NS Power Application, page 27.

¹⁴ *Ibid.*

¹⁵ Exchange rate on 3/28/2024. See for example, <https://www.bankofcanada.ca/rates/exchange/currency-converter/>.

Q How does this gross cost compare to the US National Renewable Energy Laboratory Annual Technology Baseline (NREL ATB)¹⁶ projections of costs for utility scale battery storage projects of 4-hour duration, in-service in 2025 or 2026?

A The NREL ATB lists trajectories of costs for “advanced”, “moderate”, and “conservative” categories of technological advancement and cost.¹⁷ It projects these costs on a per unit basis through 2050. The current range of capital costs (in \$2023 \$US) for 2025 or 2026 installations is roughly \$1,300 to \$2,100 per MW, for a 4-hour duration utility-scale battery. The chart below shows this comparison.



Source: Synapse, using 2023 NREL ATB and NS Power Application information.

¹⁶ The National Renewable Energy Laboratory Annual Technology Baseline (NREL ATB) is a widely-used US Department of Energy source for estimates of renewable energy resource and battery energy storage system resource costs in the industry. NS Power used this benchmark when considering cost assumptions for use in the Evergreen IRP update (see, e.g., slide 17 of the *2022 Evergreen IRP Updated Assumptions* slide deck, dated January 26, 2023). <https://irp.nspower.ca/files/key-documents/annual-evergreen-materials/2022-Evergreen-IRP-Updated-Assumptions-January-2023-Update.pdf>.

¹⁷ The three categories refer to a “refer to a range of assumptions about technology advancement and associated cost and performance”, according to NREL. <https://atb.nrel.gov/electricity/2023/index>.

1 **Q How do the underlying costs of the BESS project compare to current market-**
2 **based cost estimates for utility-scale BESS projects?**

3 **A** As seen in the graph above, the gross costs of NS Power’s BESS project are roughly
4 at the “Moderate” range, and well within the full range of estimated costs using
5 benchmark values from the NREL ATB. NREL produces annual estimates of the
6 expected cost trajectory for battery energy storage systems, as well as costs for solar
7 PV, wind energy and other technologies. The Annual Technology Baseline or ATB
8 cost information is public and is a useful benchmark to gauge the considered BESS
9 project.

10 **Q How does the use of the Canada SREP program and low-interest debt**
11 **financing from the Canadian Infrastructure Bank, and favorable tax**
12 **treatment, affect the overall costs of the BESS project?**

13 **A** The net cost of the project after considering the \$111 million SREP funding is to
14 lower the capital costs by roughly 31.4%, to \$243 million from \$354 million. This
15 percentage reduction from the gross cost is slightly less than the 33% reduction noted
16 in Natural Resource Canada’s approval letters to NS Power.¹⁸ The SREP program
17 does not include any reduction to the AFUDC component of costs.

18 The SREP program represents a dramatic reduction in costs otherwise directly borne
19 by NS Power’s ratepayers. I note that the Evergreen IRP results did not include such
20 an effect when determining the optimum resource path,¹⁹ which – as noted earlier in
21 this testimony – includes a level of battery energy storage system projects that

¹⁸ See, for example, Appendix D of the Application, page 1, concerning the Spider Lake site: “We are pleased to inform you that under the Smart Renewables and Electrification Pathways Program (the “Program”), your project has met the requirements for funding approval of an amount up to \$43,333,333 or 33% of Total Project Costs, ...”

¹⁹ The Evergreen IRP update assumptions indicate that the modeling did include the investment tax credit (ITC) effect, but not the SREP effect. See slide 16 of the *2022 Evergreen IRP Updated Assumptions*.

1 reaches 200 MW by 2031, in the currently preferred portfolio for NS Power. The low-
2 interest financing from the CIB for a portion of the costs reduces ratepayer costs for
3 capital project financing, as absent the CIB investment, NS Power would earn a
4 greater return on the debt portions of its financing, leading to increased ratepayer
5 costs. The tax benefit reduces NS Power taxes,²⁰ and thus reduces the revenue NS
6 Power would otherwise have to collect from ratepayers to cover the tax burden.

7 **Q Given these costs and these funding structures, are the projected BESS**
8 **project net costs to ratepayers reasonable?**

9 **A** Based on the current information provided in the Application and included in the
10 revenue requirements model,²¹ which incorporates the effect of the SREP program,
11 the CIB financing, and the tax treatment, yes, the net costs of the BESS project as
12 projected are reasonable.

13 **Depreciation / Sustainability**

14 **Q What is the expected life of the BESS project and what additional capital**
15 **costs beyond the initial costs are necessary to sustain the project as a reliable**
16 **energy storage resource?**

17 **A** The expected life of the project is 20 years.²² While NS Power plans for ongoing
18 sustaining capital to offset expected technical degradation²³ of battery energy storage
19 system resources,²⁴ it is not including such “augmentation” in the current

²⁰ NS Power response to NS UARB IR-11.

²¹ NS Power response to Synapse IR-1 (d).

²² NS Power response to NS UARB IR-7 (b) and NS UARB IR-36 (a).

²³ NS Power response to NS UARB IR-19 (a).

²⁴ These potential future sustaining capital costs are included in the revenue requirement model.

1 procurement process.²⁵ NS Power estimates a need for roughly \$50 million across all
2 three of the sites for sustaining capital over the period 2029-2043.²⁶

3 **Q Is NS Power’s proposed use of a depreciation rate of 5% for the BESS**
4 **project, until a depreciation study can be completed, reasonable?**

5 **A** Yes. NS Power indicates that the resource will provide 7300 lifetime cycles of
6 charging and discharging before significant degradation occurs,²⁷ which equates to
7 roughly daily cycling for 20 years. Many parts of the proposed BESS project may
8 have depreciation lifetimes longer than 20 years, while other aspects of the project
9 will have lower lifetimes. I would anticipate and expect that a full depreciation study
10 will provide refined estimates considering all of the component lifetimes of the BESS
11 project.

12 **LNTP Contract Structure and Procurement Process**

13 **Q How is NS Power acquiring the BESS project?**

14 **A** NS Power is using an outside contractor, selected through an RFP process, to provide
15 a turnkey project encompassing procurement and installation of the battery energy
16 storage system components. NS Power is using a “Limited Notice to Proceed”
17 (LNTP) contract structure to “secure a firm contract price for the engineering,
18 procurement and construction of the BESS project”.²⁸

²⁵ NS Power response to Synapse IR-6 (b).

²⁶ NS Power response to Synapse IR-5 (d).

²⁷ NS Power response to NS UARB IR-18 (g) and Synapse IR-6 (a).

²⁸ NS Power Application, page 20.

1 **Q Does the LNTP contract structure help to ensure reasonable costs for**
2 **ratepayers?**

3 **A** In my opinion, based on a review of the material available to date, yes. The LNTP
4 structure provides assurance to ratepayers because it provides for “fixed cost pricing”
5 for the main part of the project (i.e., the outsourced battery modules procurement) that
6 avoids exposure to lithium carbonate market price fluctuations, secures
7 manufacturing capability, and preserves the project schedule targets (which are
8 important to secure the SREP funding).²⁹

9 **Q What did NS Power do to ensure competitive procurement, and what is NS**
10 **Power’s ongoing process to ensure project implementation that is in the best**
11 **interests of ratepayers?**

12 **A** NS Power worked with contractor DNV to structure a competitive RFP process.³⁰
13 The process resulted in a LNTP contract structure, and NS Power has instituted a
14 “Decision Gate” project management approach to complete the procurement and
15 installation in a way that NS Power asserts will mitigate identified risks and
16 uncertainties, and “validate...confidence in the project cost estimate and schedule”.³¹
17 NS Power states that it includes risk management and “Lessons Learned and
18 Continuous Improvement”³² in this process.

²⁹ NS Power Application, pages 19-22; NS Power response to Synapse IR-10.

³⁰ NS Power Application, page 18.

³¹ NS Power Application, page 15.

³² *Ibid.*

1 **Q Will the use of this project management approach, and the LNTP contract**
2 **structure ensure that the gross costs do not rise above the currently**
3 **estimated \$354 million?**

4 **A** NS Power does not provide an explicit, affirmative assurance that this will be the
5 case, but does provide evidence that it is striving to reduce risks and complete the
6 project on time.³³ In response to the NS UARB’s question on the cost assurance, NS
7 Power does state that there is a 75% probability that the cost estimate will not be
8 exceeded, and a 25% chance that it may be exceeded.³⁴ NS Power notes a tighter
9 estimate for the BESS contractor portion of the project (i.e, AACE (Association for
10 the Advancement of Cost Engineering) Class Estimate of 1.0 and 2.0, which contain
11 tighter ranges of expected costs than other Class Estimates used for non-BESS-
12 contractor portions of the project cost).³⁵ Use of these tighter cost estimates for the
13 bulk of the expected costs contributes to greater confidence in the ultimate project
14 cost estimate.

15 **Recommendations**

16 **Q What are your recommendations to the NS UARB, given your testimony**
17 **points above?**

18 **A** Given the points I note above, in consideration of my review of NS Power’s Capital
19 Cost Application for its Battery Energy Storage System Project at this time,
20 completion of the project is in the best interests of Nova Scotia ratepayers and I
21 recommend the following:

- 22 1. Approval of NS Power’s BESS project Capital Cost Application.

³³ NS Power Application, pages 14-22, and NS Power response to NS UARB IR-35.

³⁴ NS Power response to NS UARB IR-35 (d).

³⁵ NS Power response to NS UARB IR-35 (c).

- 1 2. Approval of an interim use of 5% as an overall depreciation level for the project,
2 to be updated upon completion of a full depreciation study.
- 3 3. Close monitoring and regular reporting by NS Power on i) outcomes on the
4 ongoing LNTP contract implementation, ii) final costs, and iii) external funding
5 assurance (i.e., SREP and CIB financing) for the project.
- 6 4. NS Power reporting on the ongoing implementation of all aspects of the project
7 development, including assurances that optimum operational control and
8 communication between the Energy Control Center and the project locations has
9 been instituted. The successful integration of increasing levels of renewable
10 energy assets in Nova Scotia will depend on optimal operation of the BESS assets
11 in coordination with the other generation assets in Nova Scotia.

12 **Q Does this conclude your testimony?**

13 **A Yes.**